

O.Reg 170 SECTION 11 ANNUAL REPORT

| | |
|--|---|
| Drinking-Water System Number: | 210000078 |
| Drinking-Water System Name: | Southampton Water Treatment Plant & Distribution System |
| Drinking-Water System Owner: | Town of Saugeen Shores |
| Drinking-Water System Category: | Large Municipal Residential |
| Period being reported: | January 1 to December 31, 2006 |

| | |
|---|---|
| <p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Town of Saugeen Shores 600 Tomlinson Drive Port Elgin, Ontario N0H 2C0 519-832-2008</p> </div> | <p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <div style="border: 1px solid black; width: 100px; height: 20px; margin: 5px 0;"></div> </p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <div style="border: 1px solid black; width: 100px; height: 20px; margin: 5px 0;"></div></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p> |
|---|---|

List Drinking-Water Systems, which receive all of their drinking water from your system:

- Saugeen First Nations

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [X] No []

Indicate how you notified system users that your annual report is available, and is free of charge.

- [X] Public access/notice via the web
- [X] Public access/notice via Government Office
- [] Public access/notice via a newspaper
- [] Public access/notice via Public Request
- [] Public access/notice via a Public Library
- [] Public access/notice via other method _____

O.Reg 170 SECTION 11 ANNUAL REPORT

Describe your Drinking-Water System

Class 2 Distribution, Class 3 Treatment

The Southampton Water Treatment Plant (WTP) draws its raw water from Lake Huron through a 600 mm diameter concrete pipe. It has a wooden intake crib and flat sealed top and a 38 mm diameter solution feed for zebra mussel control inside the concrete pipe. There is an underground inlet chamber equipped with a manually cleaned raw water screen.

The low lift pumping is located on the shores of Lake Huron consisting of a raw water well with a 20 m long by 14 m wide heated superstructure housing pumping, treatment and control facilities. This includes:

- three VFD-controlled vertical turbine pumps (two duty, one standby) each rated at 104 L/s at a total dynamic head (TDH) of 37 m
- two self-cleaning strainers (one duty and one standby) with a 1.5 m³ strainer backwash wastewater storage tank
- metering pumps (one duty and one standby) each rated at 20 L/hr and a chlorine solution feed line to the diffuser located in the mouth of the intake pipe for pre chlorination and/or zebra mussel control
- a 230 kW diesel engine standby power generator set and associated equipment

The Southampton WTP is approximately 31 m long by 19 m wide enclosed building located at 140 Island St. housing all the facilities described below as well as a laboratory/control room, an electrical/mechanical room, a storage room and a washroom.

The membrane filtration system is comprised of the following components:

- four individual submerged membrane trains (each with a capacity of 5950 m³/
- five permeate pumps (four duty and one shelf standby) each rated at 73 L/s at 11.5 m TDH
- two back pulse pumps (one duty and one standby) each rated at 73 L/s at 13.5 m TDH
- two Clean-in-place (CIP) membrane wash pumps (one duty and one standby) each rated at 56 L/s at 13.5 m TDH
- two Vacuum Pumps (one duty and one standby) each rated at 22 L/s at 3.0 m TDH
- two oil free compressors rated at 37.4 m³/hr
- two air blowers (one duty and one standby) each rated at 4.4 m³/min at 31.5 kPa
- sodium hypochlorite feed system consisting of two metering pumps for recovery cleaning (one duty and one standby) with capacity of 28.1 L/min, two metering pumps for biogrowth protection (one duty and one standby) with capacity of 2.78 L/min and one 1000 L storage tank
- citric acid feed system consisting of two metering pumps (one duty and one standby) with capacity of 0.37 L/s and one 200 L storage tank
- sodium bisulfate feed system consisting of two metering pumps (one duty and one standby) with capacity of 2.06 L/min and one 60 L storage tank
- sodium hydroxide feed system consisting of two metering pumps (one duty and one standby) with capacity of 2.83 L/min and one 60 L storage tank

The Membrane Wastewater Treatment System is comprised of:

- one flocculator/clarifier including coagulation and sedimentation chambers equipped with draining system discharging sludge by gravity to sanitary sewer
- two equalization tanks with total volume of 160 m³, for membrane back pulse water equalization

O.Reg 170 SECTION 11 ANNUAL REPORT

- two tank drain/recirculation pumps (one duty and one standby) each rated at 24 L/s at 7.9 m TDH
- two pumps (one duty and one standby) rated at 22 L/s at 12 m TDH to pump equalized wastewater to clarifier
- alum feed system consisting of one storage tank and two mechanical metering pumps (one duty and one standby) each rated at 3.0 L/hr
- one 25 m³ neutralization tank
- two 8.8 m long x 7 m wide decant chambers discharging clarifier effluent by gravity to the adjacent surface drainage ditch
- sodium bisulfate feed system consisting of two metering pumps (one duty and one standby) with capacity of 0.32 L/hr and storage tank

There are two clear wells in parallel at the Water Treatment Plant with a total storage volume of 3720 m³. It is complete with intra basin baffling for storage and chlorine contact

There are also two sets of high lift pumps that consist of the following:

- three vertical turbine pumps (two duty, one standby), two pumps rated at 60 L/s at a TDH of 50 m and one pump rated at 50 L/s at a TDH of 49.7 m
- three vertical turbine pumps (two duty, one standby), each rated at 54 L/s at a TDH of 80 m

A sodium hypochlorite disinfection system is used at the Southampton WTP. The system consists of two storage tanks and two metering pumps (one duty and one standby) for post chlorination, each rated at 20 L/hr

Finally, there is a 750 kW diesel engine standby power generator set and associated equipment located in a separate room of the Plant Enclosure Building.

List all water treatment chemicals used over this reporting period

- Sodium Hypochlorite 12%
- Polyaluminumchloride
- Chlorine (gas)

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Describe

- Plant upgraded in 2006

O.Reg 170 SECTION 11 ANNUAL REPORT

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

| Incident Date | Parameter | Result | Unit of Measure | Corrective Action | Corrective Action Date |
|----------------------------|----------------|--------|-----------------|-------------------|-------------------------|
| 05/18/06 AWQI #64077 | Total Coliform | 1.0 | CFU/ 100ml | Resample | 05/18/06 Resample Ok |
| 10/29/06 AWQI #68741 | Free Chlorine | 0.11 | mg/L | Flushed System | 10/29/06 Resample Ok |

Microbiological testing done under section 8-2 during this reporting period

| | Number of Samples | Range of E.Coli Or Fecal Results (#-#) | Range of Total Coliform Results (#-#) | Number of HPC Samples Or Background Colony Counts | Range of HPC Results (#-#) Or Background Colony Counts |
|--------------|-------------------|--|---------------------------------------|---|--|
| Raw | 53 | 0-280 | 0-8000 | 1 | 0-85 |
| Treated | 53 | 0-0 | 0-0 | 53 | 0-13 |
| Distribution | 210 | 0-0 | 0-1 | 96 | 0-43 |

Operational testing done under Schedule 7, 8 or 9 during the period covered by this Annual Report.

| | Number of Grab Samples | Range of Results (#-#) |
|---------------------------------------|------------------------|------------------------|
| Turbidity | 8760 | 0.01-0.92 |
| Chlorine | 8760 | 0.2-2.0 |
| Chlorine Residual Distribution System | 938 | 0.27-2.0 |

NOTE: For continuous monitors use 8760 as the number of samples.

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

| Date of order or C of A | Parameter | Date Sampled | Result | C of A Limit | Unit of Measure |
|---|------------------------------|--------------|---------------------------|--------------|-----------------|
| C of A 0482-6U2PG4 | Suspended Solids (composite) | Monthly | Annual Average 19.45** | 15 | mg/L |
| **April, May, June, August, September and October, 2006 results were above C of A limit due to upgrades | | | | | |

O.Reg 170 SECTION 11 ANNUAL REPORT

Summary of Inorganic parameters tested during this reporting period or most recent

| Parameter | Sample Date | Result Value | Unit of Measure | Exceedance |
|-----------|-------------|--------------|-----------------|------------|
| Antimony | 01/09/06 | <0.6 | ug/L | No |
| Arsenic | 01/09/06 | <2 | ug/L | No |
| Barium | 01/09/06 | 12 | ug/L | No |
| Boron | 01/09/06 | 10 | ug/L | No |
| Cadmium | 01/09/06 | <0.1 | ug/L | No |
| Chromium | 01/09/06 | <3 | ug/L | No |
| Lead | 01/09/06 | 0.1 | ug/L | No |
| Mercury | 01/09/06 | <0.02 | ug/L | No |
| Selenium | 01/09/06 | <3 | ug/L | No |
| Sodium | 04/06/04 | 5.2 | mg/L | No |
| Uranium | 01/09/06 | <0.05 | ug/L | No |
| Fluoride | 01/14/03 | 0.18 | mg/L | No |
| Nitrite | 01/09/06 | <0.005 | mg/L | No |
| | 04/04/06 | <0.005 | mg/L | No |
| | 07/17/06 | <0.005 | mg/L | No |
| | 10/02/06 | <0.005 | mg/L | No |
| Nitrate | 01/09/06 | 1.37 | mg/L | No |
| | 04/04/06 | 0.409 | mg/L | No |
| | 07/17/06 | 0.301 | mg/L | No |
| | 10/02/06 | 0.257 | mg/L | No |

Summary of Organic parameters sampled during this reporting period or most recent

| Parameter | Sample Date | Result Value | Unit of Measure | Exceedance |
|---|-------------|--------------|-----------------|------------|
| Alachlor | 01/09/06 | <0.11 | ug/L | No |
| Aldicarb | 01/09/06 | <0.30 | ug/L | No |
| Aldrin + Dieldrin | 01/09/06 | <0.067 | ug/L | No |
| Atrazine + N-dealkylated metabolites | 01/09/06 | <0.12 | ug/L | No |
| Azinphos-methyl | 01/09/06 | <0.21 | ug/L | No |
| Bendiocarb | 01/09/06 | <0.13 | ug/L | No |
| Benzene | 01/09/06 | <0.36 | ug/L | No |
| Benzo(a)pyrene | 01/09/06 | <0.004 | ug/L | No |
| Bromoxynil | 01/09/06 | <0.094 | ug/L | No |
| Carbaryl | 01/09/06 | <0.16 | ug/L | No |
| Carbofuran | 01/09/06 | <0.37 | ug/L | No |
| Carbon Tetrachloride | 01/09/06 | <0.34 | ug/L | No |
| Chlordane (Total) | 01/09/06 | <0.11 | ug/L | No |
| Chlorpyrifos | 01/09/06 | <0.18 | ug/L | No |
| Cyanazine | 01/09/06 | <0.18 | ug/L | No |
| Diazinon | 01/09/06 | <0.081 | ug/L | No |
| Dicamba | 01/09/06 | <0.17 | ug/L | No |
| 1,2-Dichlorobenzene | 01/09/06 | <0.56 | ug/L | No |
| 1,4-Dichlorobenzene | 01/09/06 | <0.25 | ug/L | No |
| Dichlorodiphenyltrichloroethane (DDT) + metabolites | 01/09/06 | <0.14 | ug/L | No |
| 1,2-Dichloroethane | 01/09/06 | <0.32 | ug/L | No |

O.Reg 170 SECTION 11 ANNUAL REPORT

| | | | | |
|--|--------------|--------|------|----|
| 1,1-Dichloroethylene (vinylidene chloride) | 01/09/06 | <0.52 | ug/L | No |
| Dichloromethane | 01/09/06 | <1.17 | ug/L | No |
| 2-4 Dichlorophenol | 01/09/06 | <0.15 | ug/L | No |
| 2,4-Dichlorophenoxy acetic acid (2,4-D) | 01/09/06 | <0.19 | ug/L | No |
| Diclofop-methyl | 01/09/06 | <0.13 | ug/L | No |
| Dimethoate | 01/09/06 | <0.12 | ug/L | No |
| Dinoseb | 01/09/06 | <0.084 | ug/L | No |
| Diquat | 01/09/06 | <1 | ug/L | No |
| Diuron | 01/09/06 | <0.087 | ug/L | No |
| Glyphosate | 01/09/06 | <6 | ug/L | No |
| Heptachlor + Heptachlor Epoxide | 01/09/06 | <0.11 | ug/L | No |
| Linadane (Total) | 01/09/06 | <0.056 | ug/L | No |
| Malathion | 01/09/06 | <0.091 | ug/L | No |
| Methoxychlor | 01/09/06 | <0.14 | ug/L | No |
| Metolachlor | 01/09/06 | <0.092 | ug/L | No |
| Metribuzin | 01/09/06 | <0.12 | ug/L | No |
| Monochlorobenzene | 01/09/06 | <0.46 | ug/L | No |
| Paraquat | 01/09/06 | <1 | ug/L | No |
| Parathion | 01/09/06 | <0.18 | ug/L | No |
| Pentachlorophenol | 01/09/06 | <0.15 | ug/L | No |
| Phorate | 01/09/06 | <0.11 | ug/L | No |
| Picloram | 01/09/06 | <0.20 | ug/L | No |
| Polychlorinated Biphenyls(PCB) | 01/09/06 | <0.04 | ug/L | No |
| Prometryne | 01/09/06 | <0.23 | ug/L | No |
| Simazine | 01/09/06 | <0.15 | ug/L | No |
| ***THM | 2006 average | 30.75 | ug/L | No |
| Temephos | 01/09/06 | <0.31 | ug/L | No |
| Terbufos | 01/09/06 | <0.12 | ug/L | No |
| Tetrachloroethylene | 01/09/06 | <0.48 | ug/L | No |
| 2,3,4,6-Tetrachlorophenol | 01/09/06 | <0.14 | ug/L | No |
| Triallate | 01/09/06 | <0.10 | ug/L | No |
| Trichloroethylene | 01/09/06 | <0.54 | ug/L | No |
| 2,4,6-Trichlorophenol | 01/09/06 | <0.25 | ug/L | No |
| 2,4,5-Trichlorophenoxy acetic acid (2,4,5-T) | 01/09/06 | <0.14 | ug/L | No |
| Trifluralin | 01/09/06 | <0.12 | ug/L | No |
| Vinyl Chloride | 01/09/06 | <0.08 | ug/L | No |

*** Annual running quarter average

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

| Parameter | Result Value | Unit of Measure | Date of Sample |
|-----------|--------------|-----------------|----------------|
| N/A | | | |

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, small municipal non residential, large non municipal non residential)