

O.Reg 170 SECTION 11 ANNUAL REPORT

Drinking-Water System Number:	210000078
Drinking-Water System Name:	Southampton Water Treatment Plant & Distribution System
Drinking-Water System Owner:	Town of Saugeen Shores
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 1 to December 31, 2007

Complete if your Category is Large Municipal Residential or Small Municipal Residential

Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]

Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []

Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.

Town of Saugeen Shores
600 Tomlinson Drive
Port Elgin, Ontario
NOH 2C0
519-832-2008

Complete for all other Categories.

Number of Designated Facilities served:

Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []

Number of Interested Authorities you report to:

Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []

List Drinking-Water Systems, which receive all of their drinking water from your system:

- Saugeen First Nations

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes [X] No []

Indicate how you notified system users that your annual report is available, and is free of charge.

- [X] Public access/notice via the web
- [X] Public access/notice via Government Office
- [] Public access/notice via a newspaper
- [] Public access/notice via Public Request
- [] Public access/notice via a Public Library
- [] Public access/notice via other method _____

Describe your Drinking-Water System

Class 2 Distribution, Class 3 Treatment

Note: In mid June the Southampton WTP became known as the Saugeen Shores WTP. At this time water treated here was also sent to the Port Elgin Distribution System through Pressure Zone 2 and the Southampton Distribution System through Pressure Zone 1. All water testing remained the same as in previous years.

The Southampton Water Treatment Plant (WTP) draws its raw water from Lake Huron through a 600 mm diameter concrete pipe. It has a wooden intake crib and flat sealed top and a 38 mm diameter solution feed for zebra mussel control inside the concrete pipe. There is an underground inlet chamber equipped with a manually cleaned raw water screen.

The low lift pumping is located on the shores of Lake Huron consisting of a raw water well with a 20 m long by 14 m wide heated superstructure housing pumping, treatment and control facilities. This includes:

- three VFD-controlled vertical turbine pumps (two duty, one standby) each rated at 104 L/s at a total dynamic head (TDH) of 37 m
- two self-cleaning strainers (one duty and one standby) with a 1.5 m³ strainer backwash wastewater storage tank
- metering pumps (one duty and one standby) each rated at 20 L/hr and a chlorine solution feed line to the diffuser located in the mouth of the intake pipe for pre chlorination and/or zebra mussel control
- a 230 kW diesel engine standby power generator set and associated equipment

The Southampton WTP is approximately 31 m long by 19 m wide enclosed building located at 140 Island St. housing all the facilities described below as well as a laboratory/control room, an electrical/mechanical room, a storage room and a washroom.

The membrane filtration system is comprised of the following components:

- four individual submerged membrane trains (each with a capacity of 5950 m³/hr)
- five permeate pumps (four duty and one shelf standby) each rated at 73 L/s at 11.5 m TDH
- two back pulse pumps (one duty and one standby) each rated at 73 L/s at 13.5 m TDH
- two Clean-in-place (CIP) membrane wash pumps (one duty and one standby) each rated at 56 L/s at 13.5 m TDH
- two Vacuum Pumps (one duty and one standby) each rated at 22 L/s at 3.0 m TDH
- two oil free compressors rated at 37.4 m³/hr
- two air blowers (one duty and one standby) each rated at 4.4 m³/min at 31.5 kPa
- sodium hypochlorite feed system consisting of two metering pumps for recovery cleaning (one duty and one standby) with capacity of 28.1 L/min, two metering pumps for biogrowth protection (one duty and one standby) with capacity of 2.78 L/min and one 1000 L storage tank
- citric acid feed system consisting of two metering pumps (one duty and one standby) with capacity of 0.37 L/s and one 200 L storage tank
- sodium bisulfate feed system consisting of two metering pumps (one duty and one standby) with capacity of 2.06 L/min and one 60 L storage tank
- sodium hydroxide feed system consisting of two metering pumps (one duty and one standby) with capacity of 2.83 L/min and one 60 L storage tank

The Membrane Wastewater Treatment System is comprised of:

O.Reg 170 SECTION 11 ANNUAL REPORT

- one flocculator/clarifier including coagulation and sedimentation chambers equipped with draining system discharging sludge by gravity to sanitary sewer
- two equalization tanks with total volume of 160 m³, for membrane back pulse water equalization
- two tank drain/recirculation pumps (one duty and one standby) each rated at 24 L/s at 7.9 m TDH
- two pumps (one duty and one standby) rated at 22 L/s at 12 m TDH to pump equalized wastewater to clarifier
- alum feed system consisting of one storage tank and two mechanical metering pumps (one duty and one standby) each rated at 3.0 L/hr
- one 25 m³ neutralization tank
- two 8.8 m long x 7 m wide decant chambers discharging clarifier effluent by gravity to the adjacent surface drainage ditch
- sodium bisulfate feed system consisting of two metering pumps (one duty and one standby) with capacity of 0.32 L/hr and storage tank

There are two clear wells in parallel at the Water Treatment Plant with a total storage volume of 3720 m³. It is complete with intra basin baffling for storage and chlorine contact

There are also two sets of high lift pumps that consist of the following:

- three vertical turbine pumps (two duty, one standby), two pumps rated at 60 L/s at a TDH of 50 m and one pump rated at 50 L/s at a TDH of 49.7 m
- three vertical turbine pumps (two duty, one standby), each rated at 54 L/s at a TDH of 80 m

A sodium hypochlorite disinfection system is used at the Southampton WTP. The system consists of two storage tanks and two metering pumps (one duty and one standby) for post chlorination, each rated at 20 L/hr

Finally, there is a 750 kW diesel engine standby power generator set and associated equipment located in a separate room of the Plant Enclosure Building.

List all water treatment chemicals used over this reporting period

- Sodium Hypochlorite 12%
- Polyaluminumchloride
- Citric Acid

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Describe

- Plant upgraded in 2006

O.Reg 170 SECTION 11 ANNUAL REPORT

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
NA					

Microbiological testing done under section 8-2 during this reporting period

	Number of Samples	Range of E.Coli Or Fecal Results (#-#)	Range of Total Coliform Results (#-#)	Number of HPC Samples Or Background Colony Counts	Range of HPC Results (#-#) Or Background Colony Counts
Raw	24	0-38	0-500		
Treated	24	0-0	0-0	24	0-1
Distribution	93	0-0	0-0	24	0-1

***Please Note: Test results from January to June at Southampton WTP
Test results after June at Saugeen Shores WTP

Operational testing done under Schedule 7, 8 or 9 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (#-#)
Turbidity	4380	0.01-0.22
Chlorine	4380	0.06-2.0
Chlorine Residual Distribution System	274	0.4-1.82

NOTE: For continuous monitors use 8760 as the number of samples.

***Please Note: Test results from January to June at Southampton WTP
Test results after June at Saugeen Shores WTP

NOTE: Record the unit of measure if it is not milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of order or C of A	Parameter	Date Sampled	Result	C of A Limit	Unit of Measure
C of A 2084-6UNL4F	Suspended Solids (composite)	Monthly	Annual Average 4.5	15	mg/L

***Please Note: Test results from January to June at Southampton WTP
Test results after June at Saugeen Shores WTP

O.Reg 170 SECTION 11 ANNUAL REPORT

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	01/08/07	<0.2	ug/L	No
Arsenic	01/08/07	<0.2	ug/L	No
Barium	01/08/07	13.2	ug/L	No
Boron	01/08/07	14	ug/L	No
Cadmium	01/08/07	<0.06	ug/L	No
Chromium	01/08/07	0.5	ug/L	No
Lead	01/08/07	0.02	ug/L	No
Mercury	01/08/07	<0.02	ug/L	No
Selenium	01/08/07	<1	ug/L	No
Sodium	04/06/04	5.2	mg/L	No
Uranium	01/08/07	<0.23	ug/L	No
Fluoride	01/14/03	0.18	mg/L	No
Nitrite	01/08/07	<0.005	mg/L	No
	04/02/07	<0.005	mg/L	No
	07/03/07	<0.005	mg/L	No
	10/01/07	<0.005	mg/L	No
Nitrate	01/08/07	0.499	mg/L	No
	04/02/07	0.649	mg/L	No
	07/03/07	0.303	mg/L	No
	10/01/07	0.243	mg/L	No

Summary of Inorganic parameters tested during this reporting period or most recent
*****Please Note: Test results of Schedule 23 and 24 are for both Southampton plant and Saugeen Shores Plant.**

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	01/08/07	<0.11	ug/L	No
Aldicarb	01/08/07	<0.30	ug/L	No
Aldrin + Dieldrin	01/08/07	<0.067	ug/L	No
Atrazine + N-dealkylated metabolites	01/08/07	<0.12	ug/L	No
Azinphos-methyl	01/08/07	<0.21	ug/L	No
Bendiocarb	01/08/07	<0.13	ug/L	No
Benzene	01/08/07	<0.37	ug/L	No
Benzo(a)pyrene	01/08/07	<0.004	ug/L	No
Bromoxynil	01/08/07	<0.033	ug/L	No
Carbaryl	01/08/07	<0.16	ug/L	No
Carbofuran	01/08/07	<0.37	ug/L	No
Carbon Tetrachloride	01/08/07	<0.41	ug/L	No
Chlordane (Total)	01/08/07	<0.11	ug/L	No
Chlorpyrifos	01/08/07	<0.18	ug/L	No
Cyanazine	01/08/07	<0.18	ug/L	No
Diazinon	01/08/07	<0.081	ug/L	No
Dicamba	01/08/07	<0.20	ug/L	No
1,2-Dichlorobenzene	01/08/07	<0.50	ug/L	No
1,4-Dichlorobenzene	01/08/07	<0.21	ug/L	No

O.Reg 170 SECTION 11 ANNUAL REPORT

Dichlorodiphenyltrichloroethane (DDT) + metabolites	01/08/07	<0.14	ug/L	No
1,2-Dichloroethane	01/08/07	<0.43	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	01/08/07	<0.41	ug/L	No
Dichloromethane	01/08/07	<0.34	ug/L	No
2,4-Dichlorophenol	01/08/07	<0.15	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	01/08/07	<0.19	ug/L	No
Diclofop-methyl	01/08/07	<0.40	ug/L	No
Dimethoate	01/08/07	<0.12	ug/L	No
Dinoseb	01/08/07	<0.36	ug/L	No
Diquat	01/08/07	<1	ug/L	No
Diuron	01/08/07	<0.087	ug/L	No
Glyphosate	01/08/07	<6	ug/L	No
Heptachlor + Heptachlor Epoxide	01/08/07	<0.11	ug/L	No
Linadane (Total)	01/08/07	<0.056	ug/L	No
Malathion	01/08/07	<0.091	ug/L	No
Methoxychlor	01/08/07	<0.14	ug/L	No
Metolachlor	01/08/07	<0.092	ug/L	No
Metribuzin	01/08/07	<0.12	ug/L	No
Monochlorobenzene	01/08/07	<0.58	ug/L	No
Paraquat	01/08/07	<1	ug/L	No
Parathion	01/08/07	<0.18	ug/L	No
Pentachlorophenol	01/08/07	<0.15	ug/L	No
Phorate	01/08/07	<0.11	ug/L	No
Picloram	01/08/07	<0.25	ug/L	No
Polychlorinated Biphenyls(PCB)	01/08/07	<0.04	ug/L	No
Prometryne	01/08/07	<0.23	ug/L	No
Simazine	01/08/07	<0.15	ug/L	No
***THM	2007 average	34	ug/L	No
Temephos	01/08/07	<0.31	ug/L	No
Terbufos	01/08/07	<0.12	ug/L	No
Tetrachloroethylene	01/08/07	<0.45	ug/L	No
2,3,4,6-Tetrachlorophenol	01/08/07	<0.14	ug/L	No
Triallate	01/08/07	<0.10	ug/L	No
Trichloroethylene	01/08/07	<0.38	ug/L	No
2,4,6-Trichlorophenol	01/08/07	<0.25	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	01/08/07	<0.22	ug/L	No
Trifluralin	01/08/07	<0.12	ug/L	No
Vinyl Chloride	01/08/07	<0.17	ug/L	No

*** Annual average

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
N/A			

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, small municipal non residential, large non municipal non residential)