



**Ontario Clean Water Agency
Agence Ontarienne Des Eaux**

SAUGEEN SHORES WATER TREATMENT

Large Municipal Residential Drinking Water System

SCHEDULE 22 SUMMARY REPORT

For the period of
JUNE 30, 2007 TO DECEMBER 31, 2007

Prepared by the Ontario Clean Water Agency
For The Corporation of The Town of Saugeen Shores

March 31, 2008

SUMMARY

This report is a summary of water quality and quantity information submitted in accordance with Schedule 22 of Ontario's Drinking Water System Regulation for the reporting period of June 30, 2007 to December 31, 2007 for the Saugeen Shores Water Treatment Plant (formerly the Southampton Water Treatment Plant) located in the Town of Saugeen Shores.

The summary includes:

1. Any requirements of the Act and Regulation, Orders or System Approval(s) that the system failed to meet during the reporting period and the measures taken to correct each failure.
2. A summary of the quantities and flow rates of water supplied during the reporting period, including monthly averages and maximum daily flows.
3. A comparison of the average and monthly maximum daily flows to the approved capacity specified in the System Approval.

ISSUES OF NON-COMPLIANCE

There were no Ministry Inspections and no Non- Compliance issues in 2007.

ASSESSMENT OF FLOW RATES AND QUANTITIES OF WATER SUPPLIED

The following table lists the quantities and flow rates of the water supplied during the reporting period covered by this report, including monthly average and maximum daily flows and a comparison to the rated capacity and flow rates specified in the system approval:

Southampton Water Treatment Plant	June 30 - December 31
Average Day Flow (m3/day)	5504.4
Maximum Day Flow (m3/day)	9860
Average Flow Rate (L/sec)	63.7
Maximum Flow Rate (L/sec)	114.1
Design Capacity (m3/day)	18020
Approved Flow Rate (L/sec)	*208 and **300
% (Average Day/Design Capacity)	30.5
% (Maximum Day/Design Capacity)	54.7
% (Average Flow Rate/Approved Flow Rate)	30.6
% (Maximum Flow Rate/Approved Flow Rate)	54.8

- *208L/s Permit # 6375-69LP4P
- **300L/s Permit # 5384-78RK2E issued November 15,2007