



**Ontario Clean Water Agency
Agence Ontarienne Des Eaux**

PORT ELGIN WATER TREATMENT

Large Municipal Residential Drinking Water System

SCHEDULE 22 SUMMARY REPORT

For the period of:
JANUARY 1, 2008 TO OCTOBER 31, 2008

Prepared by the Ontario Clean Water Agency
For The Corporation of The Town of Saugeen Shores

March 31, 2009

SUMMARY

This report is a summary of water quality and quantity information submitted in accordance with Schedule 22 of Ontario's Drinking Water System Regulation for the reporting period of January 1, 2008 to October 31, 2008 for the Port Elgin Water Treatment located in the Municipality of Saugeen Shores. The Port Elgin Water Treatment Plant was in an idle mode since June 30, 2007 with the water supply coming from the Saugeen Shores Water Treatment Plant and is scheduled to be decommissioned October 31, 2008.

The summary includes:

1. Any requirements of the Act and Regulation, Orders or System Approval(s) that the system failed to meet during the reporting period and the measures taken to correct each failure.
2. A summary of the quantities and flow rates of water supplied during the reporting period, including monthly averages and maximum daily flows.
3. A comparison of the average and monthly maximum daily flows to the approved capacity specified in the System Approval.

ISSUES OF NON-COMPLIANCE

The following table lists the requirements of the Act, Regulations, System Approval(s) and any Order that the system failed to meet during the reporting period and the measures taken to correct each failure:

1. Continuous monitoring of each filter effluent line was not being performed for turbidity.

Action(s) Required:

No further actions required.

Response: The owner had obtained relief from regulatory requirements section 9.2 (a) Perform a regular once a day manual sampling and testing for turbidity on each filter effluent line when filters are in operation. The facility was decommissioned prior to October 31, 2008

ASSESSMENT OF FLOW RATES AND QUANTITIES OF WATER SUPPLIED

The following table lists the quantities and flow rates of the water supplied during the reporting period covered by this report, including monthly average and maximum daily flows and a comparison to the rated capacity and flow rates specified in the system approval:

Port Elgin Water Treatment Plant	January 1- October 31
Average Day Flow (m3/day)	59.74
Maximum Day Flow (m3/day)	497.00
Average Flow Rate (L/sec)	106.00
Maximum Flow Rate (L/sec)	106.00
Design Capacity (m3/day)	9164.2
Approved Flow Rate (L/sec)	106.0
% (Average Day/Design Capacity)	0.65
% (Maximum Day/Design Capacity)	5.42
% (Average Flow Rate/Approved Flow Rate)	100.00
% (Maximum Flow Rate/Approved Flow Rate)	100.00