

March 28, 2024

Ministry of the Environment, Conservation and Parks
3rd floor, 101 17th Street East
Owen Sound, Ontario
N4K 0A5

RE: 2023 Southampton Sewage Treatment Plant Annual Sewage Performance Report (CofA #3-1216-88-947) and Municipal Sewage Collection System Performance Report (CLI-ECA 093-W601) – Town of Saugeen Shores

Please see attached for the 2023 Annual Sewage and Collection System Performance Reports prepared by the Ontario Clean Water Agency on behalf of the Town of Saugeen Shores for the:

- Southampton Sewage Treatment Plant
- Town of Saugeen Shores Municipal Sewage Collection System

This report was completed in accordance with the requirements set out in CofA #3-1216-88-947 *Condition 17*, issued July 25, 1994 and Municipal Sewage Collection System CLI-ECA #093-W601 *Schedule E (4.6)*, issued January 10, 2023. Your receipt of this report by or before March 31, satisfies the regulatory requirements:

- CofA #3-1216-88-947 that “The owner shall prepare and submit a performance report to the Regional Director on an annual basis, and the submission shall be made no later than 90 days following the end of each calendar year.” and;
- CLI-ECA #093-W601 that “The Owner shall prepare an annual performance report for the Authorized System that is submitted to the Director on or before March 31st of each year and covers the period from January 1st to December 31st of the preceding calendar year.

In addition, CLI-ECA #093-W601 requires that report shall be made available, on request and without charge, to members of the public who are served by the Authorized System; and made available, by June 1 of the same reporting year, to members of the public without charge by publishing the report on the Internet, if the Owner maintains a website on the Internet. We kindly ask that notification is provided once the report is posted on the Town’s Municipal website.

Lastly, the Ministry has indicated that the Municipal Collection System ECA Annual Reports can either be prepared as a separate report or as a subsection of the Annual Sewage Report for the Wastewater Treatment Facility, attached you will find one report that satisfies the reporting requirements of both Environmental Compliance Approvals.

Should you require further clarification on the information found within the Annual Sewage Performance Report, please feel free to contact me.

Sincerely,



Dan MacLeod
Senior Operations Manager
OCWA, Georgian Highlands Region



ONTARIO CLEAN WATER AGENCY
AGENCE ONTARIENNE DES EAUX

**SOUTHAMPTON
SEWAGE TREATMENT PLANT**

ANNUAL PERFORMANCE REPORT

**For the period of
JANUARY 1, 2023 TO DECEMBER 31, 2023**

Prepared by the Ontario Clean Water Agency
For The Town of Saugeen Shores

1. System Description

The Southampton Sewage Treatment Plant began operating in its current configuration in 1996. The plant is a modified extended aeration activated sludge facility, which includes:

- Four (4) secondary clarifiers;
- Two (2) aeration tanks (oxidation ditches);
- Phosphorus removal (by continuous alum addition) and;
- Disinfection of final effluent by ultra-violet light.

The sludge is aerobically digested in the primary and secondary digester and stored in four aerated holding tanks. Digested sludge is land applied as farm fertilizer in accordance with the Non-Agricultural Source Materials (NASM) Guidelines. The plant has storage capability for approximately six months in the event that conditions are not favorable for land application.

An overview of Southampton Sewage Treatment Plant can be found in Table 1:

Table 1. Southampton Sewage Treatment Plant Overview

Facility Name	Southampton Sewage Treatment Plant
Facility Type	Modified Extended Aeration
Plant Classification	II WWT
Works Number	110001453
Design Capacity	3,046 m ³ /day
Number of Households	~1869 Residential + ~134 Commercial
Receiving Water	Saugeen River
Certificate of Approval	3-1216-88-947 (Sewage Treatment Plant)
	8-1070-95-006 (Air)

2. Monitoring and Compliance Reports

As per Section 17(a) of C of A 3-1216-88-947, *a summary of all monitoring and compliance reports submitted in the reporting period, including an overview of the success and adequacy of the sewage treatment program* is required.

During the reporting period, the following reports were submitted:

- Discharge Data Reports (Ministry of Environment, Conservation and Parks, MECP)
- Monitoring Reports (Government of Canada)
- Monthly Process and Compliance Reports (Town of Saugeen Shores)

2.1 Discharge Data Report (MECP)

The Ontario Clean Water Agency (OCWA) has an agreement with the MECP to submit quarterly discharge data for all OCWA operated municipal sewage treatment facilities 45 days at the end of each quarter. Monitoring data is submitted via the Ministry of Environment Wastewater System (MEWS). The MECP has these reports stored in a shared location where MECP Inspectors can obtain and review them. There are no limits/objectives for discharge for the quarterly Discharge Data Report.

2.2 Monitoring Report (WSER)

A monitoring report required under the Wastewater Systems Effluent Regulation (WSER) is submitted on a quarterly basis to the Government of Canada via the Effluent Regulatory Reporting Information System (ERRIS). The quarterly monitoring report requires that the following information be reported for the Southampton Sewage Treatment Plant:

- Number of days effluent was deposited
- Total volume of effluent deposited
- Average CBOD (limit of 25 mg/L)
- Average concentration of suspended solids (limit of 25 mg/L)

The monitoring reports can be found within the ERRIS. All results for average CBOD and concentration of suspended solids were below the limits set out in WSER. Testing is performed annually every August for Acute Lethality of the effluent to Rainbow Trout. The 2023 results showed 0% mortality.

2.3 Process & Compliance Report.

As per the Services Agreement (Saugeen Shores/OCWA Agreement) that OCWA has with the Town of Saugeen Shores, a Process and Compliance Report is to be submitted for each month of the year. The Monthly Process and Compliance Reports include the following information for the Southampton Sewage Treatment Plant:

<ul style="list-style-type: none">• Rated peak flow• Rated average daily flow• Average daily raw sewage flow• Maximum daily raw sewage flow	<ul style="list-style-type: none">• Scheduled maintenance• Unscheduled maintenance• Call-ins• Public inquiries and related issues
--	--

2.4 Adequacy of the Sewage Treatment Program

The current sewage treatment program provides effluent that meets all of the effluent requirements for the reports described in section 2.1 to 2.3. In addition to this, the effluent for 2023 was within all effluent limits set out in CofA 3-1216-88-947. It was also within all effluent objectives, with the exception of Total Phosphorus in August where the monthly average produced a result above the objective but below the limit. Based on this evidence, the current sewage treatment program is deemed adequate. OCWA will continue to stay within effluent limits and will continue to aim to meet effluent objectives during each reporting period.

3. Monitoring and Analytical Data

As per Section 17(b) of C of A 3-1216-88-947, *a comprehensive interpretation of all monitoring data and analytical data collected for the Southampton Sewage Treatment Plant during the reporting period compared to the effluent quality and quantity criteria described in Sections 11 and 12 of C of A 3-1216-88-947 is required.*

3.1 Sampling Frequency

Both raw sewage (influent) and effluent are sampled on a regular basis. The sampling types and frequencies are summarized in Table 2 and Table 3. The sampling frequencies either meet or exceed the requirements set out in Section 15 of C of A 3-1216-88-947.

Table 2. Raw Sewage Monitoring – Sampling Frequencies

Parameter	Sample Type	Minimum Frequency
BOD ₅ ^{2a}	24 hour Composite	Monthly
Total Suspended Solids ^{2a}	24 hour Composite	Monthly
Total Phosphorus ^{2a}	24 hour Composite	Monthly
Total Kjeldahl Nitrogen ^{2a}	24 hour Composite	Monthly
Alkalinity	24 hour Composite	Monthly

^{2a}Refer to Appendix A for monthly sample results.

Table 3. Effluent Sampling Monitoring – Sampling Frequencies

Parameters	Sample Type	Minimum Frequency
BOD ₅ ^{3a}	24 hour Composite	Monthly
Total Suspended Solids ^{3a}	24 hour Composite	Monthly
Total Phosphorus ^{3a}	24 hour Composite	Monthly
Total Kjeldahl Nitrogen	24 hour Composite	Monthly
Ammonia Nitrogen ^{3a}	24 hour Composite	Monthly
Nitrite and Nitrate ^{3a}	24 hour Composite	Monthly
Alkalinity	24 hour Composite	Monthly
pH	24 hour Composite	Monthly
E. Coli ^{3a}	Grab	Monthly

^{3a}Refer to Appendix A for monthly sample results.

3.2 Effluent Objectives and Effluent Limits

The effluent objectives as per Section 11 of C of A 3-1216-88-947 for the Southampton Sewage Treatment Plant are:

Table 4. Effluent Objectives as per Section 11 of C of A 3-1216-88-947

Effluent Parameter	Average Annual Concentration (mg/L)	Average Annual Loading (kg/day)
BOD ₅	20	60.8
Suspended Solids	20	60.8
Total Phosphorus as P	0.5 ^{4a}	1.5
<i>E.Coli</i>		150 cfu/100 mL geometric mean density for a calendar month

^{4a}The objective for Total Phosphorus as P shall be based on 'average monthly concentrations'.

The effluent limits that are to be met as per Section 12 of C of A 3-1216-88-947 for the Southampton Sewage Treatment Plant are found in Table 5. Any exceedance with the limits found in Table 5 constitutes a non-compliance with C of A 3-1216-88-947.

Table 5. Effluent Limits as per Section 12 of C of A 3-1216-88-947

Effluent Parameter	Average Concentration (mg/L)	Average Annual Loading (kg/day)
BOD ₅	25 (Annual)	76.1
Suspended Solids	25 (Annual)	76.1
Total Phosphorus as P	1 (Monthly)	3
<i>E.Coli</i>	Not to exceed 200 cfu/100 mL geometric mean density for any calendar month	

3.3 Comparison of Data to Effluent Objectives and Effluent Limits

Analytical and monitoring data for the Southampton Sewage Treatment Plant is stored in OCWA's data management system (PDM). Annual and monthly averages for flows, CBOD, BOD₅, Suspended Solids, Total Phosphorus as P, Nitrogen-series and *E.coli* can be found in Appendix A. A comparison of analytical data from effluent samples to the effluent objectives and effluent limits show the following removal efficiencies:

Table 6. 2023 Effluent Annual Average Concentrations and Removal Efficiencies

Parameter	Annual Average Concentration	Average Percent Removal Efficiency
BOD ₅ (mg/L)	3.42	96.3%
Suspended Solids (mg/L)	9.75	92.8%
Total Phosphorus as P (mg/L)	0.31	89.5%

Annual Performance Report: January 1, 2023 to December 31, 2023

Town of Saugeen Shores: Southampton Sewage Treatment Plant

C of A # 3-1216-88-947

Municipal Sewage Collection System ECA #093-W601, Issue 1 (Issue Date: January 10, 2023)

Table 7. Comparison of Effluent Limits and Objectives to Sampled Effluent for Southampton Sewage Treatment Plant (2023)

	BOD ₅				Suspended Solids				Total Phosphorus				E. Coli								
	Average Annual Concentration (mg/L)	Within Objectives (20 mg/L)	Within Limits (25 mg/L)	Average Annual Loading (kg/d)	Within Objectives (60.8 kg/d)	Within Limits (76.1 kg/d)	Average Annual Concentration (mg/L)	Within Objectives (20 mg/L)	Within Limits (25 mg/L)	Average Annual Loading (kg/d)	Within Objectives (60.8 kg/d)	Within Limits (76.1 kg/d)	Average Monthly Concentration (mg/L)	Within Objectives (0.5 mg/L)	Within Limits (1 mg/L)	Average Annual Loading (kg/d)	Within Objectives (1.5 kg/d)	Within Limits (3 kg/d)	Monthly Geometric Mean Density (mg/L)	Within Objectives (150 cfu/ 100 mL)	Within Limits (200 cfu/ 100 mL)
January	3.42	Y	Y	6.90	Y	Y	9.75	Y	Y	19.7	Y	Y	0.28	Y	Y	0.630	Y	Y	1.59	Y	Y
February													0.17	Y	Y				4.00	Y	Y
March													0.27	Y	Y				2.83	Y	Y
April													0.32	Y	Y				<2.00	Y	Y
May													0.42	Y	Y				<2.00	Y	Y
June													0.27	Y	Y				<2.00	Y	Y
July													0.40	Y	Y				<2.00	Y	Y
August													0.52	N	Y				8.62	Y	Y
September													0.24	Y	Y				<2.00	Y	Y
October													0.46	Y	Y				<2.00	Y	Y
November													0.17	Y	Y				<2.00	Y	Y
December													0.17	Y	Y				<2.00	Y	Y

3.4 Additional Monitoring Parameters

The following parameters do not have limits or objectives but are monitored on a regular basis (see Section 3.1 for sampling frequency) as required by C of A 3-1216-88-947. Table 8, Table 9 and Table 10 summarize the monitoring data for the reporting period. The raw sewage and effluent values are similar to the results from the previous year.

Table 8. Raw Sewage Monitoring Parameters as required by C of A 3-1216-88-947 for Southampton Sewage Treatment Plant, 2023

Parameter	Average	Minimum	Maximum
BOD ₅ ^{8a} (mg/L)	88.29	42.00	133.00
Total Suspended Solids ^{8a} (mg/L)	150.04	80.00	353.00
Total Phosphorus ^{8a} (mg/L)	2.96	1.98	5.59
Total Kjeldahl Nitrogen ^{8a} (mg/L)	22.51	14.20	38.10
Alkalinity (mg/L as CaCO ₃)	274.92	243.00	319.00

^{8a}Refer to Appendix A for monthly sample results.

Table 9. Effluent Monitoring Parameters as required by C of A 3-1216-88-947 for Southampton Sewage Treatment Plant, 2023

Parameters	Average	Minimum	Maximum
Total Kjeldahl Nitrogen (mg/L)	0.78	0.50	2.60
Total Ammonia Nitrogen ^{9a} (mg/L)	0.10	0.10	0.20
Nitrite and Nitrate ^{9a} (mg/L)	19.67	13.90	25.10
Alkalinity (mg/L as CaCO ₃)	105.42	45.00	157.00
pH	7.90	7.45	8.18

^{9a}Refer to Appendix A for monthly sample results. For sewage the optimal pH range for effluent is between 6.0 and 9.5.

Table 10. Influent Flow Monitoring as required by C of A 3-1216-88-947 for Southampton Sewage Treatment Plant, 2023

Parameters	Result (m ³)	CofA Limits	Percentage of Limits
Annual Average Flow	2,148	3,042	70.6%
Peak Flow Rate	4,161	6,084	68.4%

4. Effluent Quality Assurance and Control

As per 17(c) of C of A 3-1216-88-947, a summary of effluent quality assurance or control measures taken during the reporting period is required.

All laboratory analyzed raw sewage and effluent samples (Section 3.1) are analyzed by SGS Canada Inc., which is an ISO 17025 accredited laboratory. In-house tests are conducted for monitoring purposes by licensed operators using standardized methods. The results from in-house tests are used to determine treatment efficiency and to effectively maintain process control. Calibrations and preventative maintenance are performed on facility equipment and monitoring equipment, see Section 10 for more details. In addition to sample analysis, preventative maintenance is scheduled for equipment at the

sewage treatment plant and pumping stations at regular frequency (dependent on the equipment and type of maintenance). Maintenance activities are scheduled in the work management system (WMS).

5. Major Maintenance Activities

As per 17(d) of C of A 3-1216-88-947, *a summary of all maintenance carried out on any major structure, equipment, apparatus, or mechanisms that form part of the facility during the reporting period* is required. For 2023, major maintenance activities that occurred include:

- Aeration ditch clean out
- Clarifier wear shoes purchased
- 100hp blower bearings replaced
- Channel aeration blower replaced

6. Operating Challenges

As per 17(e) of C of A 3-1216-88-947, *the operating problems encountered and corrective actions taken during the reporting period* are to be identified.

There were no operating challenges, bypasses or spills at the Southampton Sewage Treatment Plant during the reporting period.

7. Proposed Alterations, Extensions or Replacements

As per 17(f) of C of A 3-1216-88-947, *a summary of any proposed alteration, extension or replacement in the process of operations of the sewage treatment plant to be completed over the next reporting period which may require approval under the Ontario Water Resources Act (OWRA)* is required. The following alterations, extensions/replacements are proposed for 2024, some of which may not require approval under OWRA:

- Headworks upgrade/expansion
- Pump Station #1 upgrades
- Pump Station #3 Force main and PS rehab

8. Sludge Generation


As per 17(g) of C of A 3-1216-88-947, *a tabulation of the volume of sludge generated in the reporting period and an outline of anticipated volumes to be generated over the next reporting period* is required.

According to the Daily Record of Sludge Haulage, a total volume of 3,022 m³ of sludge was generated from the Southampton Sewage Treatment Plant and applied to agricultural land by Bartels Environmental Services during the reporting period. Table 11 summarizes the sludge haulage volumes for 2023. The hauling and spreading of sludge from the Southampton sewage treatment plant was conducted by Bartel's Environmental Services. A chemical analysis of the sludge/biosolids quality can be found in Appendix B.

Table 11. Volume of Sludge Generated from Southampton Sewage Treatment Plant in 2023

NASM Site	Volume of Biosolids (m ³)	Hauler	Haulage Dates
23706	1,364	Bartel's Environmental	May 15, 16, 17
24198	910	Bartel's Environmental	September 18, 19, 20
25069	748	Bartel's Environmental	November 20, 21

Based on a linear regression with an R² value of 88%, the anticipated volume to be generated over the next reporting period is approximately 3,180 m³.

**Figure 1.** Southampton Sewage Treatment Plant Haulage Volumes (2012 to 2023)

9. Sludge Handling

As per 17(h) of C of A 3-1216-88-947, an *outline of the sludge handing methods and disposal areas to be utilized over the next reporting period* are to be specified.

In 2023 sludge was handled and hauled by Bartels Environmental Inc. and applied to Ontario Ministry of Agriculture, Food and Rural Affairs (OMAFRA) approved Non-Agricultural Source Material Plans (NASM Plans) based on Ontario Regulation 338/09 made under the Nutrient Management Act, 2002. NASM Plans under the Nutrient Management Act are issued to the owner (farmer) who is responsible for managing this plan with assistance from the NASM Plan Developer. See Appendix C for Sludge Haulage Records for Southampton Sewage Treatment Plant.

Grab samples of digested (aerobic) sludge were collected as the sludge was being transferred from the digester to the hauling truck (see Appendix B for laboratory results). With the exception of total solids and volatile suspended solids, all other samples were analyzed by SGS Canada Inc. Sludge analyses showed that the sludge met the quality criteria specified in the Ontario Guidelines for the Utilization of Biosolids and Other Wastes on Agricultural Land (Guidelines). A summary of sludge haulage and sample and quality report results are attached in Appendix B & C.

10. Calibration and Maintenance Procedures

As required by 17(i) of C of A 3-1216-88-947, *an evaluation of the calibration and maintenance procedures conducted on all monitoring equipment* is required.

All in-house monitoring equipment is calibrated/verified as per manufacturer's recommendations. Monitoring and metering equipment is also calibrated by a third party on an annual basis. Preventative maintenance is scheduled for all equipment at the sewage treatment plant and pumping stations at regular frequency (frequency depends on the equipment and type of maintenance). Maintenance activities are scheduled within the WMS, upon completion, Operators set the work order status to complete. On a monthly basis, preventative work orders are reviewed for completion.

On May 15 & 16, 2023 SCG Flowmetrix performed an annual third party instrument verification of the final effluent and influent flow meters. On April 14 and October 17, 2023, SPD Sales Limited calibrated the gas detection equipment. On April 12, 2023 SPD Sales Limited calibrated spectrophotometer and probes used in the Southampton Sewage Treatment Plant. The meter/probes were cleaned, parts replaced, the devices were calibrated and verified that the devices were performing to factory specifications, where applicable. All records for the above mentioned calibrations/ verifications can be found in Appendix D.

11. Modifications for Performance and Reliability

As per 17(j) of C of A 3-1216-88-947 *an evaluation for the need for modifications to the Southampton Sewage Treatment Plant to improve performance and reliability and to minimize upsets and bypasses* is required.

Southampton Sewage Treatment Plant was within all effluent objectives (with the exception of Total Phosphorus in August) and limits for the entire reporting period. However, considering the systems age and the projected growth of the municipality, modifications for increased capacity are required in the near future.

12. Municipal Sewage Collection System – Annual Performance Report

This report was prepared in accordance with the requirements of the Environmental Compliance Approval for a Municipal Sewage Collection Systems, Schedule E, Section 4.6.1.

Municipal Sewage Collection System ECA #	093-W601, Issue 1
Sewage Works	Saugeen Shores Municipal Sewage Collection System
Collection System Owner	The Corporation of the Town of Saugeen Shores
Reporting Period	January 1, 2023 to December 31, 2023

Is the Annual Report available to the public at no charge on a website on the Internet?

Yes

Note: As per Schedule E, Section 4.7.1 of CLI-ECA #093-W601, the annual performance report must be made available, on request and without charge, to members of the public who are served by the Authorized System; and 4.7.2 must be made available, by June 1st of the same reporting year, to members of the public without charge by publishing the report on the Internet, if the Owner maintains a website on the Internet.

Annual Performance Report: January 1, 2023 to December 31, 2023

Town of Saugeen Shores: Southampton Sewage Treatment Plant

C of A # 3-1216-88-947

Municipal Sewage Collection System ECA #093-W601, Issue 1 (Issue Date: January 10, 2023)

Location where Annual Performance Report required under CLI-ECA #093-W601 Schedule E will be available for inspection. (CLI-ECA #093-W601, Schedule E, Section 4.7.1 & 4.7.2):

- Town of Saugeen Shores Municipal Office, 600 Tomlinson Dr., Port Elgin, ON N0H 2C0
- <https://www.saugeenshores.ca/en/town-hall/water-reports.aspx#2022-WaterWastewater-Reports>

Pursuant to Schedule E, sections 4.6.3 to 4.6.9, this Annual Performance Report shall:

- a) If applicable, includes a summary of all required monitoring data along with an interpretation of the data and any conclusion drawn from the data evaluation about the need for future modifications to the Authorized System or system operations.
- b) If applicable, include a summary of any operating problems encountered and corrective actions taken.
- c) Includes a summary of all calibration, maintenance, and repairs carried out on any major structure, Equipment, apparatus, mechanism, or thing forming part of the Municipal Sewage Collection System.
- d) Include a summary of any complaints related to the Sewage Works received during the reporting period and any steps taken to address the complaints.
- e) Include a summary of all Alterations to the Authorized System within the reporting period that are authorized by this Approval including a list of Alterations that pose a Significant Drinking Water Threat.
- f) Include a summary of all Collection System Overflow(s) and Spill(s) of Sewage.
- g) Includes a summary of efforts made to reduce Collection System Overflows, Spills, STP Overflows, and/or STP Bypasses.

12.1 Description of the Works

The Town of Saugeen Shores Municipal Sewage Collection System consists of two separate subsystems; the Port Elgin Wastewater Collection Subsystem and the Southampton Wastewater Collection Subsystem. For the purposes of this annual report, only the Southampton Wastewater Collection Subsystem will be included. For further information on the Port Elgin Wastewater Collection System, please refer to the Port Elgin WPCP 2023 Annual Performance Report.

The Southampton Wastewater Collection Subsystem consists of sewage works for the collection and transmission of sewage, consisting of trunk sewers, separate sewers, sewage pumping stations, and forcemains, with discharge into the Southampton Water Pollution Control Plant.

The sewage pumping station in Authorized System include:

- Southampton Sewage Pumping Station #1 – located at 86 Saugeen St. Consists of drywell, control building, two pumps, a stand-by diesel generator and discharges to the Southampton Sewage Treatment Plant.
- Southampton Sewage Pumping Station #2 – located at 3 Beach Rd. Consists of wetwell, control building, two pumps, a stand-by diesel generator and discharges to a gravity sewer on Huron St and then flows to PS #1.

- Southampton Sewage Pumping Station #3 – located at 315 Clarendon St. Consists of wetwell, two pumps, a stand-by diesel generator and discharges to the Southampton Sewage Treatment Plant into the same forcemain as PS #1.
- Southampton Sewage Pumping Station #4 – located at 489 Eckford Ave. Consists of wetwell, two pumps, a stand-by diesel generator (shared with Turner St. Control Station) and discharges to a gravity sewage collection system near Blanchfield and Oak St. which is delivered to PS #5.
- Southampton Sewage Pumping Station #5 – located at 130 Shore Rd. Consists of wetwell, two pumps, a stand-by diesel generator (shared with Turner St. Control Station) and discharges to the Southampton Sewage Treatment Plant.

12.2 Summary of Monitoring Data and Interpretation

No monitoring data was required within the municipal sewage collection system for the reporting period.

12.3 Summary of Operating Problems Encountered and Corrective Actions Taken

There were no operating problems encountered within the municipal sewage collection system for the reporting period.

12.4 Summary of Calibration, Maintenance and Repairs

All in-house monitoring equipment is calibrated/verified as per manufacturer's recommendations. Monitoring and metering equipment is also calibrated by a third party on an annual basis. Preventative maintenance is scheduled for all equipment at the sewage treatment plant and pumping stations at regular frequency (frequency depends on the equipment and type of maintenance). Maintenance activities are scheduled within the work management system Maximo, upon completion, operators set the work order to complete. On a monthly basis, preventative work orders are reviewed for completion.

On May 15 & 16, 2023 SCG Flowmetrix performed an annual third party instrument verification of the final effluent and influent flow meters. On April 14 and October 17, 2023, SPD Sales Limited calibrated the gas detection equipment. On April 12, 2023 SPD Sales Limited calibrated spectrophotometer and probes used in the Southampton Sewage Treatment Plant. The meter/probes were cleaned, parts replaced, the devices were calibrated and verified that the devices were performing to factory specifications, where applicable. All records for the above mentioned calibrations/ verifications can be found in Appendix D.

All records for the above mentioned calibrations/ verifications can be found in Appendix D.

Major maintenance activities for the sewage pump stations can be found in section 12.6 of this report.

12.5 Community Complaints Received in Relation to the Sewage Works

During the reporting period, OCWA staff received six (6) community complaints. Typically, the Town will address complaints by verifying if there are odours in the surrounding area physically by attending the location of the complaint and creating an odour log. The sewers are flushed routinely and the

operators of the plant ensure that an odour neutralizer is periodically added to the sewage collection system. See Appendix E for details on community complaints.

12.6 Alterations to the Authorized System

For 2023, major maintenance activities that occurred within the Authorized System include:

- Spools and valves replaced at PS#1 (required external pumps to bypass wetwell and direct sewage to WWTP)
- New Pump purchase for PS#3
- Old pump for PS#3 rebuilt

There were no alterations performed within the Authorized System that pose a Significant Drinking Water Threat.

12.7 Summary of Collection System Overflow(s) and Spill(s) of Sewage

There were no collection system overflow or spill events that occurred during the reporting period.

12.8 Efforts Made to Reduce Collection System Overflows, Spills, STP Overflows, and/or STP Bypasses.

The sewage pump stations are equipped with alarm monitoring for high flow events. Preventative maintenance procedures are in place to ensure the sewage pump stations are operating as designed and include:

- Wet well cleanouts
- Daily inspections of pump stations
- Annual cleanouts
- Pump inspections
- Alarm testing
- Generator inspection and maintenance



Appendix A

Performance Assessment Report

Performance Assessment Report

03/08/2024

From 1/1/2023 to 12/31/2023 11:59:59 PM

Page 1 of 2

5613 SOUTHAMPTON WASTEWATER TREATMENT FACILITY 110001453

	1 / 2023	2 / 2023	3 / 2023	4 / 2023	5 / 2023	6 / 2023	7 / 2023	8 / 2023	9 / 2023	10 / 2023	11 / 2023	12 / 2023	<--Total-->	<--Avg-->	<--Max-->	<--Criteria-->	
Flows																	
Raw Flow: Total - Raw Sewage m³/d	67,772.04	60,008.73	62,873.51	78,305.05	67,216.39	54,586.61	65,496.62	62,292.07	58,057.57	73,920.81	64,856.04	68,777.15	784,162.59			0.00	
Raw Flow: Avg - Raw Sewage m³/d	2,186.19	2,143.17	2,028.18	2,610.17	2,168.27	1,819.55	2,112.79	2,009.42	1,935.25	2,384.54	2,161.87	2,218.62		2,148.39		6,083.00	
Raw Flow: Max - Raw Sewage m³/d	2,943.21	3,004.07	2,584.96	4,161.31	2,569.61	2,182.43	2,315.27	2,216.42	2,206.22	3,374.97	2,700.56	3,126.99			4,161.31	0.00	
Raw Flow: Count - Raw Sewage m³/d	31.00	28.00	31.00	30.00	31.00	30.00	31.00	31.00	30.00	31.00	30.00	31.00	365.00			0.00	
Eff. Flow: Total - Final Effluent m³/d	63,069.00	54,969.00	58,931.00	73,174.00	62,607.00	53,353.00	63,061.00	60,100.00	55,428.00	69,634.00	59,128.00	63,282.00	736,736.00			0.00	
Eff. Flow: Avg - Final Effluent m³/d	2,034.48	1,963.18	1,901.00	2,439.13	2,019.58	1,778.43	2,034.23	1,938.71	1,847.60	2,246.26	1,970.93	2,041.35		2,018.45			
Eff. Flow: Max - Final Effluent m³/d	2,894.00	2,886.00	2,502.00	4,642.00	2,795.00	2,206.00	2,235.00	2,216.00	2,256.00	3,373.00	2,584.00	3,120.00			4,642.00	0.00	
Eff Flow: Count - Final Effluent m³/d	31.00	28.00	31.00	30.00	31.00	30.00	31.00	31.00	30.00	31.00	30.00	31.00	365.00			0.00	
Carbonaceous Biochemical Oxygen Demand: CBOD																	
Eff: Avg cBOD5 - Final Effluent mg/L	3.33	3.00	2.50	<	9.50	2.50	2.50	2.50	2.33	2.00	2.00	2.00		3.04	9.50		
Eff: # of samples of cBOD5 - Final Effluent	3.00	1.00	2.00		2.00	2.00	2.00	2.00	3.00	2.00	1.00	2.00	24.00			0.00	
Loading: cBOD5 - Final Effluent kg/d	6.782	5.890	4.753	<	23.172	5.049	4.446	5.086	4.524	3.695	4.493	3.942	4.083		6.14	23.17	
Biochemical Oxygen Demand: BOD5																	
Raw: Avg BOD5 - Raw Sewage mg/L	109.67	97.00	100.50		120.00	83.00	89.00	87.50	84.67	76.00	81.00	56.00	67.00		87.61	120.00	0.00
Raw: # of samples of BOD5 - Raw Sewage	3.00	1.00	2.00		2.00	2.00	2.00	2.00	3.00	2.00	1.00	2.00	2.00	24.00			0.00
Eff: Avg BOD5 - Final Effluent mg/L	4.67	3.00	3.50		9.00	3.50	2.00	2.50	2.33	2.00	3.00	2.00	3.00		3.42	9.00	25.00
Loading: BOD5 - Final Effluent kg/d	9.494	5.890	6.654		21.952	7.069	3.557	5.086	4.524	3.695	6.739	3.942	6.124		6.90	21.95	76.100
Percent Removal: BOD5 - Raw Sewage %	95.74	96.91	96.52		92.50	95.78	97.75	97.14	97.24	97.37	96.30	96.43	95.52		96.27	97.75	0.00
Total Suspended Solids: TSS																	
Raw: Avg TSS - Raw Sewage mg/L	217.67	165.00	200.00		251.50	115.50	119.00	140.00	155.67	111.00	105.00	85.00	83.50		145.74	251.50	0.00
Raw: # of samples of TSS - Raw Sewage	3.00	1.00	2.00		2.00	2.00	2.00	2.00	3.00	2.00	1.00	2.00	2.00	24.00			0.00
Eff: Avg TSS - Final Effluent mg/L	15.00	12.00	15.00		12.50	9.50	5.00	6.00	9.00	4.50	18.00	6.00	7.50		9.75	18.00	25.00
Eff: # of samples of TSS - Final Effluent	3.00	1.00	2.00		2.00	2.00	2.00	2.00	3.00	2.00	1.00	2.00	2.00	24.00			0.00
Loading: TSS - Final Effluent kg/d	30.517	23.558	28.515		30.489	19.186	8.892	12.205	17.448	8.314	40.433	11.826	15.310		19.68	40.43	76.100
Percent Removal: TSS - Raw Sewage %	93.11	92.73	92.50		95.03	91.77	95.80	95.71	94.22	95.95	82.86	92.94	91.02		92.80	95.95	0.00
Total Phosphorus: TP																	
Raw: Avg TP - Raw Sewage mg/L	2.27	2.38	2.63		2.53	2.82	3.28	3.68	4.71	3.07	2.94	2.30	2.07		2.89	4.71	0.00
Raw: # of samples of TP - Raw Sewage	3.00	1.00	2.00		2.00	2.00	2.00	2.00	3.00	2.00	1.00	2.00	2.00	24.00			0.00
Eff: Avg TP - Final Effluent mg/L	0.28	0.17	0.27		0.32	0.42	0.27	0.40	0.52	0.24	0.46	0.17	0.17		0.31	0.52	1.00
Eff: # of samples of TP - Final Effluent	3.00	1.00	2.00		2.00	2.00	2.00	2.00	3.00	2.00	1.00	2.00	2.00	24.00			0.00

From 1/1/2023 to 12/31/2023 11:59:59 PM

Loading: TP - Final Effluent kg/d		0.563		0.334		0.504		0.781		0.838		0.480		0.804		1.002		0.443		1.033		0.335		0.337		0.63		1.03		3.000
Percent Removal: TP - Raw Sewage %		87.83		92.86		89.92		87.33		85.26		91.77		89.25		89.04		92.18		84.35		92.59		92.03		89.53		92.86		0.00

Nitrogen Series

Raw: Avg TKN - Raw Sewage mg/L	17.97	19.50	18.95	17.45	22.25	24.40	26.65	33.63	23.10	23.60	18.45	19.90		22.15	33.63	0.00
Raw: # of samples of TKN - Raw Sewage	3.00	1.00	2.00	2.00	2.00	2.00	2.00	3.00	2.00	1.00	2.00	2.00	2.00	2.00	2.00	0.00
Eff: Avg TAN - Final Effluent mg/L	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.15	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	0.15
Eff: # of samples of TAN - Final Effluent	3.00	1.00	2.00	2.00	2.00	2.00	2.00	3.00	2.00	1.00	2.00	2.00	2.00	2.00	2.00	0.00
Loading: TAN - Final Effluent kg/d	< 0.203	< 0.196	< 0.190	< 0.244	< 0.303	< 0.178	< 0.203	< 0.194	< 0.185	< 0.225	< 0.197	< 0.204	< 0.21	< 0.21	< 0.30	
Eff: Avg NO3-N - Final Effluent mg/L	17.77	13.90	18.45	17.40	20.90	24.90	22.85	22.23	23.35	14.10	16.90	16.10		19.07	24.90	0.00
Eff: # of samples of NO3-N - Final Effluent	3.00	1.00	2.00	2.00	2.00	2.00	2.00	3.00	2.00	1.00	2.00	2.00	2.00	2.00	2.00	0.00
Eff: Avg NO2-N - Final Effluent mg/L	< 0.03	< 0.03	< 0.03	< 0.34	< 0.71	< 0.05	< 0.06	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.12	< 0.71	0.00
Eff: # of samples of NO2-N - Final Effluent	3.00	1.00	2.00	2.00	2.00	2.00	2.00	3.00	2.00	1.00	2.00	2.00	2.00	2.00	2.00	0.00

Disinfection

Eff: GMD E. Coli - Final Effluent cfu/100mL



Appendix B

Sludge Quality Sample Analysis

29-May-2023


OCWA-Bruce (Southampton WPCP)

Attn : Karla Young

P.O. Box 760
Southampton, ON
N0H 2L0, CanadaPhone: 519-797-2561
Fax:pdf**Date Rec. :** 16 May 2023
LR Report: CA12755-MAY23**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Completed Date	4: Analysis Completed Time	5: BSLQ BSLQ-Sludge Quality Hauled Sludge
Sample Date & Time					15-May-23 08:35
Temperature Upon Receipt [°C]	---	---	---	---	13.0
Total Solids [mg/L]	19-May-23	14:00	23-May-23	15:45	36000
Total Solids (ASH) [mg/L]	19-May-23	14:00	23-May-23	15:45	14600
Total Solids (LOI) [mg/L]	19-May-23	14:00	23-May-23	15:45	21500
pH [pH Units]	17-May-23	07:34	18-May-23	08:58	5.39
Total Kjeldahl Nitrogen [as N mg/L]	17-May-23	16:30	19-May-23	14:11	860
Ammonia+Ammonium (N) [as N mg/L]	16-May-23	18:00	17-May-23	13:29	< 1
Nitrite (as N) [mg/L]	18-May-23	12:54	29-May-23	09:48	1.7
Nitrate (as N) [mg/L]	18-May-23	12:54	29-May-23	09:48	480
Nitrate + Nitrite (as N) [mg/L]	18-May-23	12:54	29-May-23	09:48	480
Arsenic [mg/L]	19-May-23	15:36	24-May-23	12:45	0.2
Cadmium [mg/L]	19-May-23	15:36	24-May-23	12:45	0.038
Cobalt [mg/L]	19-May-23	15:36	24-May-23	12:45	0.14
Chromium [mg/L]	19-May-23	15:36	24-May-23	12:45	0.65
Copper [mg/L]	19-May-23	15:36	24-May-23	12:45	16
Mercury [mg/L]	19-May-23	15:36	24-May-23	12:45	0.009
Potassium [mg/L]	19-May-23	15:36	24-May-23	12:45	115
Molybdenum [mg/L]	19-May-23	15:36	24-May-23	12:45	0.20
Nickel [mg/L]	19-May-23	15:36	24-May-23	12:45	0.59
Phosphorus (Total) [mg/L]	19-May-23	15:36	24-May-23	12:45	1140
Lead [mg/L]	19-May-23	15:36	24-May-23	12:45	0.5
Selenium [mg/L]	19-May-23	15:36	24-May-23	12:45	0.2
Zinc [mg/L]	19-May-23	15:36	24-May-23	12:45	16
E. Coli [cfu/1g dried wgt]	16-May-23	15:50	18-May-23	11:59	<278
E. Coli [cfu/100mL]	16-May-23	15:50	18-May-23	11:59	< 1000

Note: Metals and mercury were analyzed on the as-received sample. The E. coli value reported in CFU/1g dried weight was calculated using Total Solids and CFU/100mL.



Carrie Greenlaw

*Project Specialist,
Environment, Health & Safety*

04-October-2023


OCWA-Bruce (Southampton WPCP)

Attn : Karla Young

P.O. Box 760
Southampton, ON
N0H 2L0, CanadaPhone: 519-797-2561
Fax:pdf**Date Rec. :** 19 September 2023
LR Report: CA12650-SEP23**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Completed Date	4: Analysis Completed Time	5: BSLQ BSLQ-Sludge Quality Hauled Sludge
Sample Date & Time					18-Sep-23 07:50
Temperature Upon Receipt [°C]	---	---	---	---	14.0
Total Solids [mg/L]	22-Sep-23	17:32	26-Sep-23	09:14	27900
Total Solids (ASH) [mg/L]	22-Sep-23	17:32	26-Sep-23	09:14	12600
Total Solids (LOI) [mg/L]	22-Sep-23	17:32	26-Sep-23	09:14	15400
pH [pH Units]	20-Sep-23	10:04	21-Sep-23	09:46	6.00
Total Kjeldahl Nitrogen [as N mg/L]	20-Sep-23	09:46	22-Sep-23	12:44	746
Ammonia+Ammonium (N) [as N mg/L]	20-Sep-23	14:58	21-Sep-23	10:11	1.6
Nitrite (as N) [mg/L]	22-Sep-23	19:51	25-Sep-23	14:53	< 3
Nitrate (as N) [mg/L]	22-Sep-23	19:51	25-Sep-23	14:53	210
Nitrate + Nitrite (as N) [mg/L]	22-Sep-23	19:51	25-Sep-23	14:53	210
Arsenic [mg/L]	29-Sep-23	14:59	03-Oct-23	15:01	0.2
Cadmium [mg/L]	29-Sep-23	14:59	03-Oct-23	15:01	0.030
Cobalt [mg/L]	29-Sep-23	14:59	03-Oct-23	15:01	0.10
Chromium [mg/L]	29-Sep-23	14:59	03-Oct-23	15:01	0.55
Copper [mg/L]	29-Sep-23	14:59	03-Oct-23	15:01	14
Mercury [mg/L]	29-Sep-23	14:59	03-Oct-23	15:01	0.011
Potassium [mg/L]	29-Sep-23	14:59	03-Oct-23	15:01	78
Molybdenum [mg/L]	29-Sep-23	14:59	03-Oct-23	15:01	0.12
Nickel [mg/L]	29-Sep-23	14:59	03-Oct-23	15:01	0.44
Phosphorus (Total) [mg/L]	29-Sep-23	14:59	03-Oct-23	15:01	837
Lead [mg/L]	29-Sep-23	14:59	03-Oct-23	15:01	0.4
Selenium [mg/L]	29-Sep-23	14:59	03-Oct-23	15:01	0.1
Zinc [mg/L]	29-Sep-23	14:59	03-Oct-23	15:01	15
E. Coli [cfu/1g dried wgt]	19-Sep-23	16:16	21-Sep-23	09:55	3584
E. Coli [cfu/100mL]	19-Sep-23	16:16	21-Sep-23	09:55	10000

Note: Metals and mercury were analyzed on the as-received sample. The E. coli value reported in CFU/1g dried weight was calculated using Total Solids and CFU/100mL.



Carrie Greenlaw
Carrie Greenlaw
Project Specialist,
Environment, Health & Safety

30-November-2023

OCWA-Bruce (Southampton WPCP)

Attn : Karla Young

P.O. Box 760
 Southampton, ON
 N0H 2L0, Canada

Phone: 519-797-2561
 Fax:pdf

Date Rec. : 21 November 2023
LR Report: CA12644-NOV23


Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Completed Date	4: Analysis Completed Time	5: BSLQ BSLQ-Sludge Quality Hauled Sludge
Sample Date & Time					20-Nov-23 08:05
Temperature Upon Receipt [°C]	---	---	---	---	7.0
Total Solids [mg/L]	21-Nov-23	18:43	23-Nov-23	11:14	25400
Total Solids (ASH) [mg/L]	21-Nov-23	18:43	23-Nov-23	11:14	8170
Total Solids (LOI) [mg/L]	21-Nov-23	18:43	23-Nov-23	11:14	17200
pH [pH Units]	22-Nov-23	16:02	23-Nov-23	12:48	6.15
Total Kjeldahl Nitrogen [as N mg/L]	22-Nov-23	13:57	24-Nov-23	14:12	797
Ammonia+Ammonium (N) [as N mg/L]	22-Nov-23	13:56	23-Nov-23	12:42	< 1
Nitrite (as N) [mg/L]	23-Nov-23	08:48	27-Nov-23	13:30	< 3
Nitrate (as N) [mg/L]	23-Nov-23	08:48	27-Nov-23	13:30	190
Nitrate + Nitrite (as N) [mg/L]	23-Nov-23	08:48	27-Nov-23	13:30	190
Arsenic [mg/L]	29-Nov-23	05:01	30-Nov-23	12:57	0.1
Cadmium [mg/L]	29-Nov-23	05:01	30-Nov-23	12:57	0.026
Cobalt [mg/L]	29-Nov-23	05:01	30-Nov-23	12:57	0.07
Chromium [mg/L]	29-Nov-23	05:01	30-Nov-23	12:57	0.41
Copper [mg/L]	29-Nov-23	05:01	30-Nov-23	12:57	12
Mercury [mg/L]	29-Nov-23	05:01	30-Nov-23	12:57	0.009
Potassium [mg/L]	29-Nov-23	05:01	30-Nov-23	12:57	60
Molybdenum [mg/L]	29-Nov-23	05:01	30-Nov-23	12:57	0.12
Nickel [mg/L]	29-Nov-23	05:01	30-Nov-23	12:57	0.35
Phosphorus (Total) [mg/L]	29-Nov-23	05:01	30-Nov-23	12:57	811
Lead [mg/L]	29-Nov-23	05:01	30-Nov-23	12:57	0.4
Selenium [mg/L]	29-Nov-23	05:01	30-Nov-23	12:57	0.1
Zinc [mg/L]	29-Nov-23	05:01	30-Nov-23	12:57	15
E. Coli [cfu/1g dried wgt]	21-Nov-23	15:46	23-Nov-23	15:10	6299
E. Coli [cfu/100mL]	21-Nov-23	15:46	23-Nov-23	15:10	16000

Note: Metals and mercury were analyzed on the as-received sample. The E. coli value reported in CFU/1g dried weight was calculated using Total Solids and CFU/100mL.



Carrie Greenlaw
Carrie Greenlaw
Project Specialist,
Environment, Health & Safety



Appendix C

Check sheets of Sludge Haulage

Daily Record of Sludge Haulage

Page 1 of

Plant/ Facility Name <i>Southampton</i>	Area <i>Saugeen Shores</i>	Date <i>May 15-23</i>
Carrier/ Hauler <i>Bartels - ENU</i>	Site # <i>23706</i>	<small>NOTE: ONLY ONE SHEET PER SITE</small>

Load No.	Time		Load Volume (m ³)	Carrier Information		Driver Initials
	In	Out		Vehicle License #	Trailer #	
1	12:00	12:30	44	415	T-17	BB
2	12:50	1:15	44	127	T20	BB
3	1:30	1:40	44	415	T-17	BB
4	2:00	2:30	44	127	T20	BB
5	2:50	3:10	44	415	T-17	BB
6	3:20	3:50	44	127	T20	BB
7	4:00	4:20	44	415	T-17	BB
8	4:30	5:00	44	127	T20	BB
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
Daily Total		352 m ³				

REMARKS

Date May 15/23

OCWA Rep.
Signature Gusty Becker

Carrier/ Hauler
Signature BKuntz

Daily Record of Sludge Haulage

Page of

Plant/ Facility Name <i>Southampton</i>	Area <i>Saugeen Shores</i>	Date <i>May 16/23</i>
Carrier/ Hauler <i>Bartels Env</i>	Site # <i>23706</i>	<small>NOTE: ONLY ONE SHEET PER SITE</small>

Load No.	Time		Load Volume (m ³)	Carrier Information		Driver Initials
	In	Out		Vehicle License #	Trailer #	
1	6:30 am	7:00 am	44	415	T-17	DH
2	7:00	7:30	44	127	T-20	BB
3	7:35	7:55	44	415	T-17	DH
4	8:15	8:45	44	127	T-20	BB
5	9:00	9:35	44	415	T-17	DH
6	11:00	11:30	44	127	T-20	BB
7	11:45	12:10	44	415	T-17	DH
8	12:00	12:30	44	127	T-20	BB
9	12:40	1:10	44	415	T-17	DH
10	1:10	1:35	44	127	T-20	BB
11	1:50	2:15	44	415	T-17	DH
12	2:15	2:40	44	127	T-20	BB
13	2:55	3:15	44	415	T-17	DH
14	3:30	4:00	44	127	T-20	BB
15	4:05	4:30	44	415	T-17	DH
16						
17						
18						
19						
20						
Daily Total			660 m ³			

REMARKS

Date *May 16/23*

OCWA Rep.
Signature

Gretchen Becker

Carrier/ Hauler
Signature

Bartels Env

Daily Record of Sludge Haulage

 Page of

Plant/ Facility Name <i>Southampton</i>	Area <i>Saugeen Shores</i>	Date <i>May 17/23</i>
Carrier/ Hauler <i>Bar-Jets Env</i>	Site # <i>23706</i>	<u>NOTE: ONLY ONE SHEET PER SITE</u>

Load No.	Time		Load Volume (m ³)	Carrier Information		Driver Initials
	In	Out		Vehicle License #	Trailer #	
1	6:30	7:00	4/4	127	T-20	BB
2	7:05	7:30	4/4	4115	T-17	DH
3	7:50	8:15	44	127	T-20	BB
4	8:20	8:45	44	4115	T-17	DH
5	8:50	9:15	44	127	T-20	BB
6	9:50	10:10	44	414	T-17	DH
7	10:15	10:40	44	127	T-20	BB
8	10:50	11:20	461	4115	T-17	DH
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
Daily Total		352				

REMARKS

 Date May 17/23

 OCWA Rep.
 Signature

Gustyn Becker

 Carrier/ Hauler
 Signature

Daily Record of Sludge Haulage

Page of

Plant/ Facility Name <u>Southampton</u>	Area <u>Bugoyne</u>	Date <u>Sept 18/23</u>
Carrier/ Hauler <u>Brands Environmental</u>	Site # <u>24198</u>	<u>NOTE: ONLY ONE SHEET PER SITE</u>

Load No.	Time		Load Volume (m ³)	Carrier Information		Driver Initials
	In	Out		Vehicle License #	Trailer #	
1	8:00	8:20	44	4282	T14	JH
2	8:30	8:50	44	127	T20	BB
3	12:50	1:15	44	4115	T26	DH
4	1:25	1:50	44	4282	T14	JH
5	1:30	2:00	44	127	T20	BB
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
Daily Total						

REMARKS

Date Sept 18/23

OCWA Rep.
Signature

Carrier/ Hauler
Signature

Daily Record of Sludge Haulage

Page of

Plant/ Facility Name <u>Southampton</u>	Area <u>Burgoyne</u>	Date <u>Sept 19-23</u>
Carrier/ Hauler <u>Bartels Environmental</u>	Site # <u>24198</u>	<small>NOTE: ONLY ONE SHEET PER SITE</small>

Load No.	Time		Load Volume (m ³)	Carrier Information		Driver Initials
	In	Out		Vehicle License #	Trailer #	
1	7:00	7:20	441	4115	T-26	DD
2	7:20	7:40	44	127	720	BB
3	7:40	8:00	44	4282	T14	JH
4	8:20	8:40	441	4115	T-26	JH
5	8:45	9:10	44	127	720	BB
6	9:35	9:55	44	4282	T14	JH
7	10:10	10:30	441	4115	T-26	DD
8	10:30	10:50	44	127	720	BB
9	11:00	11:20	44	4282	T14	JH
10	11:30	11:50	44	4115	T-26	JH
11	12:00	12:20	44	127	720	BB
12	12:25	12:45	44	4282	T14	JH
13	1:10	1:30	441	4115	T-26	DD
14	2:00	2:30	44	127	720	BB
15	2:50	3:10	44	4282	T14	JH
16						
17						
18						
19						
20						
Daily Total						

REMARKS

Date

Sept 20-23

OCWA Rep.
Signature

Justine

Carrier/ Hauler
Signature

Bartels Environmental

Daily Record of Sludge Haulage

Page of

Plant/ Facility Name <u>Southampton</u>		Area <u>Burgoyne</u>	Date <u>Sept 20-23</u>			
Carrier/ Hauler <u>Bartels Environmental</u>		Site # <u>241198</u>	<small>NOTE: ONLY ONE SHEET PER SITE</small>			
Load No.	Time		Load Volume (m ³)	Carrier Information		Driver Initials
	In	Out		Vehicle License #	Trailer #	
1	7:00	7:20	30	L115	T-26	DBH
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
Daily Total						

REMARKS

Date Sept 20-23

OCWA Rep.
Signature

Carrier/ Hauler
Signature

Daily Record of Sludge Haulage

Page 1 of

Plant/ Facility Name	Area	Date
Southampton	Saugeen Shores	NOV21/23

Carrier/ Hauler	Site #
Bartels Environmental	Asoba

NOTE: ONLY ONE SHEET PER SITE

Load No.	Time		Load Volume (m ³)	Carrier Information		Driver Initials
	In	Out		Vehicle License #	Trailer #	
1	6:45	7:10	44	127	T-20	BB
2	7:15	7:35	44	115	T-26	DH
3	8:00	8:20	44	127	T-20	BB
4	8:30	8:50	44	115	T-26	DH
5	9:25	9:45	44	127	T-20	BB
6			(2)			
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						

Daily Total

220

REMARKS

Date

NOV21/23

OCWA Rep.
Signature

Just Post

Carrier/ Hauler
Signature

D

Daily Record of Sludge Haulage

Plant/ Facility Name <u>Southampton</u>	Area <u>Peg Saageen Shores</u>	Date <u>Nov 20/23</u>
Carrier/ Hauler <u>Bartels Environmental</u>	Site # <u>25069</u>	<u>NOTE: ONLY ONE SHEET PER SITE</u>

Load No.	Time		Load Volume (m ³)	Carrier Information		Driver Initials
	In	Out		Vehicle License #	Trailer #	
1	8:15	8:30	44	127	T20	BB
2	8:40	9:00	44	415	T-26	DH
3	9:15	9:30	44	127	T20	BB
4	10:00	10:15	44	415	T-26	DH
5	10:50	11:10	44	127	T20	BB
6	11:25	11:45	44	415	T-26	DH
7	12:00	12:20	44	127	T20	BB
8	12:35	12:55	44	415	T-26	DH
9	1:20	1:40	44	127	T20	BB
10	1:50	2:10	44	415	T-26	DH
11	2:30	2:50	44	127	T20	BB
12	3:00	3:20	44	415	T-26	DH
13						
14						
15						
16						
17						
18						
19						
20						

Daily Total

528 m³

REMARKS

Date

Nov 20/23OCWA Rep.
SignatureJust PostCarrier/ Hauler
SignatureBartels Environmental



Appendix D

Calibration Reports



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southhampton						
Plant Name and address:	86 Saugeen St ON						
Service Date:	14-Apr-23	Instrument Type:	AIT	W.O. Number:	220902-0002	Asset#:	NA
Due Date:	14-Oct-23	Manufacturer:	MSA				
Follow-Up Required:	No	Model:	ULTIMA - X 5000				
As Left Status:	Initial Condt	Serial #:	000100200115001C				
Instrument Visual Inspection:		Range:	0-25 O2%, 0- 50 PPM H2S	Output:	4-20 mA		
Mechanical Inspection:	OK	Tag Infomration:	NA				
Electrical Inspection:	OK	Description:	Monitoring Oxygen Gas & H2S Gas				
As found Display information:	OK	Process/Location Description:	Saugeen St pumping station				

Instrument Information:								
Sensor No.:	Sensor Type	Unit	Zero Gas Value	Span Gas Value	Range Gas Value	Caution Setpoint	Warning Setpoint	Alarm Setpoint
1	O2	%	0	20.80	0-25	NA	19.50	18.00
2	H2S	PPM	0	40	0-50	NA	5.00	15.00

Sensor No.:	Gas	Gas Value	As Found	Deviation	As Left	Deviation
Sensor 1	Zero	0	0	0.00%	0	0.00%
	Span	20.8	20.80	0.00%	20.80	0.00%
Sensor 2	Zero	0	0	0.00%	0	0.00%
	Span	40	38.00	5.00%	40	0.00%

Comments			Test Equipment Used		
			Name / Type	Serial and Due Date	
Calibrated successfully			CalGas Oxygen 20.8% Vol	304-402190658-1, Aug-2025	
			CalGas H2S 40 PPM	304-402184551-1, Aug-2023	
Other Outputs Tested:	Not tested		Technician Name	Witness Name	
Loop Check Performed:	Not Tested		Vaibhav Patel	Jusin Porter	
Within Specification:	No		Date:	14-Apr-23	Date: 14-Apr-23



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southampton						
Plant Name and address:	86 Saugeen St ON						
Service Date:	14-Apr-23	Instrument Type:	AIT	W.O. Number:	220902-0002	Asset#:	NA
Due Date:	14-Oct-23	Manufacturer:	MSA				
Follow-Up Required:	No	Model:	ULTIMA - X 5000				
As Left Status:	Initial Condt	Serial #:	000100200117001B				
Instrument Visual Inspection:		Range:	0-100% LEL	Output:	4-20 mA		
Mechanical Inspection:	OK	Tag Infomration:	NA				
Electrical Inspection:	OK	Description:	Monitoring Methane Gas				
As found Display information:	OK	Process/Location Description:	Saugeen St pumping station				

Instrument Information:	
Sensor Type and unit:	LEL, %
Zero Gas Value:	0
Span Gas Value:	50
Gas Range Value:	0-100
Caution Level:	NA
Warning Level:	10
Alarm Level:	20

Gas	Gas Value	As Found	Deviation	As Left	Deviation
Zero	0	0	0.00%	0	0.00%
Span	50	52	4.00%	50	0.00%

Comments	Test Equipment Used			
	Name / Type		Serial and Due Date	
Calibrated successfully	CalGas Methane 2.5% Vol (50%)		304-402205618-1, Aug-2025	
	CalGas Oxygen 20.8% Vol		304-402190658-1, Aug-2025	
Other Outputs Tested:	Not tested	Technician Name	Witness Name	
Loop Check Performed:	Not Tested	Vaibhav Patel	Jusin Porter	
Within Specification:	Yes	Date:	14-Apr-23	Date: 14-Apr-23



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southampton						
Plant Name and address:	18 Caroline st, Southampton						
Service Date:	14-Apr-23	Instrument Type:	AIT	W.O. Number:	220902-0002	Asset#:	NA
Due Date:	14-Oct-23	Manufacturer:	MSA				
Follow-Up Required:	No	Model:	ALTAIR 4X				
As Left Status:	Initial Condt	Serial #:	00356341				
Instrument Visual Inspection:		Range:	0-100%,0-100PPM,0-50PPM,0-25%	Output:	NA		
Mechanical Inspection:	OK	Tag Infomration:	NA				
Electrical Inspection:	OK	Description:	MSA ALTAIR 4X Handheld gas				
As found Display information:	OK	Process/Location Description:	Operator room				

Instrument Information:								
Sensor No.:	Sensor Type	Unit	Zero Gas Value	Span Gas Value	Range Gas Value	Caution Setpoint	Warning Setpoint	Alarm Setpoint
1	LEL	%	0	50	100	NA	10.00	10.00
2	CO	PPM	0	100	100	NA	10.00	20.00
3	H2S	PPM	0	25	50	NA	5.00	15.00
4	O2	%	0	18.0	25	NA	19.50	18.00

Sensor No.:	Gas	Gas Value	As Found	Deviation	As Left	Deviation
Sensor 1	Zero	0	0	0.00%	0	0.00%
	Span	50	86	72.00%	58	50.00%
Sensor 2	Zero	0	0	0.00%	0	0.00%
	Span	100	97	-3.00%	60	100.00%
Sensor 3	Zero	0	0	0.00%	0	0.00%
	Span	25	25	0.00%	20	25.00%
Sensor 4	Zero	0	0	0.00%	0	0.00%
	Span	18.0	18	0.00%	18	18.00%

Comments			Test Equipment Used		
			Name / Type	Serial and Due Date	
Calibrated Successfully			MSA Quadgas	304-402541925-1 ; Sept-2026	
			(100 PPM CO, 25 PPM H2S, 50 %LEL, 18% O2)		
Other Outputs Tested:		Not tested	Technician Name	Witness Name	
Loop Check Performed:		Not tested	Vaibhav Patel	Justin Porter	
Within Specification:		Yes	Date: 14-Apr-23	Date: 14-Apr-23	



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southampton						
Plant Name and address:	18 Caroline st, Southampton						
Service Date:	14-Apr-23	Instrument Type:	AIT	W.O. Number:	220902-0002	Asset#:	NA
Due Date:	14-Oct-23	Manufacturer:	MSA				
Follow-Up Required:	No	Model:	ALTAIR 4X				
As Left Status:	Initial Condt	Serial #:	199193				
Instrument Visual Inspection:		Range:	0-100%,0-100PPM,0-50PPM,0-25%	Output:	NA		
Mechanical Inspection:	OK	Tag Infomration:	NA				
Electrical Inspection:	OK	Description:	MSA ALTAIR 4X Handheld gas				
As found Display information:	OK	Process/Location Description:	Operator room				

Instrument Information:								
Sensor No.:	Sensor Type	Unit	Zero Gas Value	Span Gas Value	Range Gas Value	Caution Setpoint	Warning Setpoint	Alarm Setpoint
1	LEL	%	0	50	100	10.00	10.00	
2	CO	PPM	0	100	100	10.00	20.00	
3	H2S	PPM	0	25	50	5.00	15.00	
4	O2	%	0	18.0	25	19.50	18.00	

Sensor No.:	Gas	Gas Value	As Found	Deviation	As Left	Deviation
Sensor 1	Zero	0	0	0.00%	0	0.00%
	Span	50	92	84.00%	50	0.00%
Sensor 2	Zero	0	-30	0.00%	0	0.00%
	Span	100	95	-5.00%	100	0.00%
Sensor 3	Zero	0	0	0.00%	0	0.00%
	Span	25	25	0.00%	25	0.00%
Sensor 4	Zero	0	0	0.00%	0	0.00%
	Span	18.0	20.4	13.33%	18	0.00%

Comments			Test Equipment Used		
			Name / Type	Serial and Due Date	
Calibrated Successfully			MSA Quadgas	304-402541925-1 ; Sept-2026	
			(100 PPM CO, 25 PPM H2S, 50 %LEL, 18% O2)		
Other Outputs Tested:		Not tested	Technician Name	Witness Name	
Loop Check Performed:		Not tested	Vaibhav Patel	Justin Porter	
Within Specification:		Yes	Date: 14-Apr-23	Date: 14-Apr-23	



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southampton					
Plant Name and address:	Southampton WWTP - 18 Caroline St W, southampton, ON					
Service Date:	12-Apr-23	Instrument Type:	AIT	W.O. Number:	230295-0001	Asset#:
Due Date:	12-Apr-24	Manufacturer:	Hach			
Follow-Up Required:	No	Model:	2100P			
As Left Status:	Initial Condt	Serial #:	030300030469			
Instrument Visual Inspection:		Range:	0-1000 NTU	Output:	NA	
Mechanical Inspection:	OK	Tag Infomration:	NA			
Electrical Inspection:	OK	Description:	Portable Turbidity Analyzer			
As found Display information:	OK	Process/Location Descrpition:	Operator Room			

Instrument Information:	
Unit of measurement:	NTU
Range of the meter:	1000
Verification Standard Value:	10
Calibration Standard Solution 1:	20
Calibration Standard Solution 2:	100
Calibration Standard Solution 3:	800
Verification as found & left value:	10.3/10
Verification result:	Pass

Turbidity Standard	Output Value	As Found	Deviation	As Left	Deviation
20.00	20.00	19.30	-3.50%	20.30	1.50%
100.00	100.00	98.10	-1.90%	99.60	-0.40%
800.00	800.00	783.00	-2.13%	793.00	-0.88%

Comments	Test Equipment Used			
	Name / Type	Serial No.	Due Date	
Calibrated Successfully	10 NTU	Lot #A3052	Jun-24	
	20 NTU	Lot #A3041	Jun-24	
	100 NTU	Lot #A3055	Jun-24	
	800 NTU	Lot # A3065	Jun-24	
		Technician Name	Witness Name	
		Vaibhav Patel	Justin Porter	
Calibration Result:	Pass	Date:	12-Apr-23	Date: 12-Apr-23



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southampton								
Plant Name and address:	Southampton WWTP - 18 Caroline St W, southampton, ON								
Service Date:	12-Apr-23	Instrument Type:	AIT	W.O. Number:	230295-0001	Asset#:	NA		
Due Date:	12-Apr-24	Manufacturer:	Hach						
Follow-Up Required:	No	Model:	Transmitter:	SC200	Sensor:	CL10			
As Left Status:	Initial Condt	Serial #:	Transmitter:	1210C00498781	Sensor:	140545001879			
Instrument Visual Inspection:		Range:	0-20 mg/l		Output:	4-20 mA			
Mechanical Inspection:	OK	Tag Infomration:	NA						
Electrical Inspection:	OK	Description:	Total Chlorine Analyzer						
As found Display information:	OK	Process/Location Descrpition:	Low Lift						

Instrument Information:	
Unit of measurement:	mg/l
Range	20
DPD Kit Value:	0.53

DPD Kit Reading	Chlorine Meter Reading	As Found	Deviation	As Left	Deviation
0.53	0.37	0.37	-43.24%	0.53	0.00%

Comments	Test Equipment Used			
	Name / Type	Serial No.	Due Date	
Adjust the value and Verified SuccessFully.	DPD kit	19110A001768	Aug-23	
Other Outputs Tested:	Not tested	Technician Name	Witness Name	
Loop Check Performed:	Not tested	Vaibhav Patel	Nicole Moore	
Within Specification:	Yes	Date:	12-Apr-23	Date: 12-Apr-23



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southampton						
Plant Name and address:	Southampton WWTP - 18 Caroline St W, southampton, ON						
Service Date:	12-Apr-23	Instrument Type:	AIT	W.O. Number:	230295-0001	Asset#:	NA
Due Date:	12-Apr-24	Manufacturer:	Hach				
Follow-Up Required:	No	Model:	DR300 - LPV445.97.00110				
As Left Status:	Initial Condt	Serial #:	20030A001000				
Instrument Visual Inspection:		Range:	NA	Output:	NA		
Mechanical Inspection:	OK	Tag Infomration:	NA				
Electrical Inspection:	OK	Description:	Portable Chlorine Meter				
As found Display information:	OK	Process/Location Descrpition:	Operator Room				

Instrument Information:		
Unit of measurement:	mg/l	
Range of the meter:	NA	
Calibration Standard Solution 1:	0.21	+0.09
Calibration Standard Solution 2:	0.91	+0.10
Calibration Standard Solution 3:	1.59	+0.14

Chlorine Standard	Output Value	As Found	Deviation	As Left	Deviation
0.21	0.21	0.21	0.00%	0.21	0.00%
0.91	0.91	0.89	-2.20%	0.91	0.00%
1.59	1.59	1.61	1.26%	1.59	0.00%

Comments	Test Equipment Used		
	Name / Type	Serial No.	Due Date
Calibrated Successfully	DPD Chlrine LR Standard Kit	Lot #A2027	Feb-24
Technician Name		Witness Name	
Vaibhav Patel		Justine Porter	
Calibration Result:	Pass	Date:	12-Apr-23
		Date:	12-Apr-23



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southampton								
Plant Name and address:	Southampton WWTP - 18 Caroline St W, southampton, ON								
Service Date:	12-Apr-23	Instrument Type:	AIT	W.O. Number:	230295-0001	Asset#:	NA		
Due Date:	12-Apr-24	Manufacturer:	Hach						
Follow-Up Required:	No	Model:	Pocket Colorimeter II						
As Left Status:	Initial Condt	Serial #:	18030E350957						
Instrument Visual Inspection:		Range:	NA		Output:	NA			
Mechanical Inspection:	OK	Tag Infomration:	NA						
Electrical Inspection:	OK	Description:	Portable Chlorine Meter						
As found Display information:	OK	Process/Location Descrpition:	Operator Room						

Instrument Information:		
Unit of measurement:	mg/l	
Range of the meter:	NA	
Calibration Standard Solution 1:	0.21	+0.09
Calibration Standard Solution 2:	0.91	+.10
Calibration Standard Solution 3:	1.59	+.14

Chlorine Standard	Output Value	As Found	Deviation	As Left	Deviation
0.21	0.21	0.21	0.00%	0.21	0.00%
0.91	0.91	1.89	107.69%	1.89	107.69%
1.59	1.59	1.59	0.00%	1.59	0.00%

Comments	Test Equipment Used		
	Name / Type	Serial No.	Due Date
Verified SuccessFully.	DPD Chlorine LR Standard Kit	Lot #A2027	Feb-24
Technician Name		Witness Name	
Vaibhav Patel		Justine Porter	
Verification Result	Pass	Date:	12-Apr-23
		Date:	12-Apr-23



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southampton						
Plant Name and address:	Southampton WWTP - 18 Caroline St W, southampton, ON						
Service Date:	12-Apr-23	Instrument Type:	AIT	W.O. Number:	230295-0001	Asset#:	NA
Due Date:	12-Apr-24	Manufacturer:	Hach				
Follow-Up Required:	No	Model:	Transmitter: HQ2200	Sensor:	PHC101		
As Left Status:	Initial Condt	Serial #:	Transmitter: 213282200038	Sensor:	220452561210		
Instrument Visual Inspection:	Range:	0-14 PH		Output:	NA		
Mechanical Inspection:	OK	Tag Infomration:	NA				
Electrical Inspection:	OK	Description:	Portable PH Probe				
As found Display information:	OK	Process/Location Description:	Operator Room				

Instrument Information:	
Range:	14
Slope:	96%
Offset:	-4.3 mV

Input	Input %	Temp. °C	As Found	Deviation	As Left	Deviation
4.01	28.64%	20.80	4.03	0.50%	4.01	0.00%
7.00	50.00%	20.80	7.05	0.71%	6.98	-0.29%
10.00	71.43%	20.80	10.60	6.00%	9.98	-0.20%

Comments	Test Equipment Used					
	Name / Type	Serial No.	Due Date			
Calibrated Successfully	pH 4.00 Cat 2283449	Lot#A2045	Feb-26			
	pH 7.00 Cat2283549	Lot #A2059	Mar-24			
	pH 10.00 Cat2283649	Lot #A2341	Dec-23			
Technician Name		Witness Name				
Vaibhav Patel		Justin Porter				
Calibration Result:	Pass	Date:	12-Apr-23	Date: 12-Apr-23		



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southampton							
Plant Name and address:	Southampton WWTP - 18 Caroline St W, southampton, ON							
Service Date:	12-Apr-23	Instrument Type:	AIT	W.O. Number:	230295-0001	Asset#:	NA	
Due Date:	12-Apr-24	Manufacturer:	Hach					
Follow-Up Required:	No	Model:	Transmitter:	HQ2200	Sensor:	LDO		
As Left Status:	Initial Condt	Serial #:	Transmitter:	213282200038	Sensor:	90292592005		
Instrument Visual Inspection:		Range:	NA			Output:	NA	
Mechanical Inspection:	OK	Tag Infomration:	NA					
Electrical Inspection:	OK	Description:	Portable DO Probe					
As found Display information:	OK	Process/Location Description:	Operator Room					

Instrument Information:	
Range	Auto
Temperature:	20.0 Degree C
Offset	0
Slope	101.50%

Input		mg/L		As Found	Deviation	As Left	Deviation
Dissolved oxygen from Air	Should be between 8 to10 mg/l	9.03		8.52	-5.65%	8.52	-5.65%

Comments	Test Equipment Used		
	Name / Type	Serial No.	Due Date
Air calibration was performed.			
As left reading was 8.52 mg/l in air.			
Disolved oxygen in Air depends on the various parameter such as temperature, pressure and weather conditins.			
	Technician Name	Witness Name	
	Vaibhav Patel	Justin Porter	
Calibration Result:	Pass	Date: 12-Apr-23	Date: 12-Apr-23



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southampton						
Plant Name and address:	Southampton WWTP - 18 Caroline St W, southampton, ON						
Service Date:	12-Apr-23	Instrument Type:	AIT	W.O. Number:	230295-0001	Asset#:	NA
Due Date:	12-Apr-24	Manufacturer:	Hach				
Follow-Up Required:	No	Model:	Transmitter:	SC200	Sensor:	LDO	
As Left Status:	Initial Condt	Serial #:	Transmitter:	1412CO0116822	Sensor:	150470000034	
Instrument Visual Inspection:		Range:	NA			Output:	4-20 mA
Mechanical Inspection:	OK	Tag Infomration:	NA				
Electrical Inspection:	OK	Description:	Portable DO Probe				
As found Display information:	OK	Process/Location Description:	Operator Room				

Instrument Information:	
Range at 4 mA:	Auto Range
Range at 20 mA:	Auto Range
Temperature:	21 Degree C
Slope correction	0.69

Input	mg/L	As Found	Deviation	As Left	Deviation
Dissolved oxygen from Air	Should be between 8 to10 mg/l	9.03	11.40	26.25%	9.50

Comments	Test Equipment Used			
	Name / Type	Serial No.	Due Date	
Air calibration was performed.				
As left reading was 9.5 mg/l in air.				
Disolved oxygen in Air depends on the various parameter such as temperature, pressure and weather conditins.				
Other Outputs Tested:	Not tested	Technician Name	Witness Name	
Loop Check Performed:	Not tested	Vaibhav Patel	Justin Porter	
Within Specification:	Yes	Date: 12-Apr-23	Date: 12-Apr-23	



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southampton								
Plant Name and address:	Southampton WWTP - 18 Caroline St W, southampton, ON								
Service Date:	12-Apr-23	Instrument Type:	AIT	W.O. Number:	230295-0001	Asset#:	NA		
Due Date:	12-Apr-24	Manufacturer:	Hach						
Follow-Up Required:	No	Model:	Transmitter:	SC200	Sensor:	LDO			
As Left Status:	Initial Condt	Serial #:	Transmitter:	1412CO0116822	Sensor:	152160000061			
Instrument Visual Inspection:		Range:	NA		Output:	4-20 mA			
Mechanical Inspection:	OK	Tag Infomration:	NA						
Electrical Inspection:	OK	Description:	Portable DO Probe						
As found Display information:	OK	Process/Location Description:	Operator Room						

Instrument Information:	
Range at 4 mA:	Auto Range
Range at 20 mA:	Auto Range
Temperature:	21 Degree C
Slope correction	0.76

Input	mg/L	As Found	Deviation	As Left	Deviation
Dissolved oxygen from Air	Should be between 8 to10 mg/l	9.03	12.50	38.43%	9.76

Comments	Test Equipment Used			
	Name / Type	Serial No.	Due Date	
Air calibration was performed.				
As left reading was 9.76 mg/l in air.				
Disolved oxygen in Air depends on the various parameter such as temperature, pressure and weather conditins.				
Other Outputs Tested:	Not tested	Technician Name	Witness Name	
Loop Check Performed:	Not tested	Vaibhav Patel	Justin Porter	
Within Specification:	Yes	Date: 12-Apr-23	Date: 12-Apr-23	



AS FOUND CERTIFICATION
FORWARD FLOW DIRECTION
PASS

CLIENT DETAIL

CUSTOMER OCWA - Georgian Highlands - Bruce Hub
CONTACT Dan MacLeod
Senior Operations Manager
18 Caroline Street West
Southampton, ON N0H 2L0
Ph: 519-379-0431
E: danmacleod@ocwa.com

VER. BY - FM Paris Machuk / Mike White

Quality Management Standards Information -
Reference equipment and instrumentation used to
conduct this verification test is found in our AC-
QMS document at the time this test was

EQUIPMENT DETAIL

[MUT] MANUFACTURER Krohne
MODEL IFC 100W
SERIAL NUMBER C12501984
FUSE Wall switch to right of unit

PLANT ID Southampton WWTP
METER ID Return Activated Sludge #1 (West Side)
FIT ID N/A
CLIENT TAG N/A
OTHER ORG #5613
GPS COORDINATES N44 30.103 W081 21.236

VERIFICATION DATE May 16, 2023
CAL. FREQUENCY Annual
CAL. DUE DATE May, 2024

PROGRAMMING PARAMETERS

DIAMETER (DN)	mm	150
F.S. FLOW - MAG	LPS	172.6
F.S. RANGE - O/P	LPS	63.09
CAL. K-FACTOR	GKL	6.4107

FORWARD TOTALIZER INFORMATION

AS FOUND	5479253.23	M3
AS LEFT	5479311.57	M3
DIFFERENCE	58.34	M3

TEST CRITERIA

AS FOUND CERTIFICATION TEST	Yes
FORWARD FLOW DIRECTION	Yes
ALLOWABLE [%] ERROR	5

COMPONENTS TESTED

CONVERTER DISPLAY	yes
mA OUTPUT	yes
TOTALIZER	Yes
ACCURACY BASED ON [% o.r.]	yes
ERROR DOCUMENTED IN THIS REPORT; BASED ON % o.r.	

Zero Offset Flow LPS 0.0000

FLOW TUBE SIMULATION

		0.0	0.5	1.0	2.0	m/s
		0.0	5.0	10.0	20.0	% F.S. Flow
		0.0	13.7	27.4	54.7	% F.S. Range
REF. FLOW RATE		0.0		8.6	17.3	34.5 LPS
MUT [Reading]		0.0		8.6	17.2	34.5 LPS
MUT [Difference]		0.0		0.0	-0.1	0.0 LPS
MUT [% Error]		n/a		-0.38	-0.38	%
mA OUTPUT		4.000		6.189	8.378	12.757 mA
MUT [Reading]	min.	4.000 mA	3.995	6.176	8.370	12.747 mA
MUT [Difference]	max.	20.000 mA	-0.005	-0.013	-0.008	-0.010 mA
MUT [% Error]			-0.12	-0.21	-0.10	-0.08 %
TOTALIZER - REF. FLOW RATE					34.530	LPS
TOTALIZER [MUT]					2	M3
TEST TIME					57.89	SECONDS
CALC. TOTALIZER					1.999	M3
ERROR					0.05	%

COMMENTS

QUALITY MANAGEMENT STANDARDS INFO.		
[QMS] INFORMATION	IDENT.	ID #
[REFERENCE] FTS	KRO	1
PROCESS METER	PM	20
ANALOG METER	AM	N/A
STOP WATCH	SW	Yes

RESULTS

TEST	AVG % o.r.	PASS FAIL
DISPLAY	-0.28	PASS
mA OUTPUT	-0.13	PASS
TOTALIZER	0.05	PASS

This report reflects the test results of the overall accuracy for the above flow converter using the specified manufacturers flow tube simulator to within the specified tolerance as identified within this report.



AS FOUND CERTIFICATION
FORWARD FLOW DIRECTION
PASS

CLIENT DETAIL

CUSTOMER OCWA - Georgian Highlands - Bruce Hub
CONTACT Dan MacLeod
Senior Operations Manager
18 Caroline Street West
Southampton, ON N0H 2L0
Ph: 519-379-0431
E: danmacleod@ocwa.com

VER. BY - FM Paris Machuk / Mike White

Quality Management Standards Information -
Reference equipment and instrumentation used to
conduct this verification test is found in our AC-
QMS document at the time this test was

EQUIPMENT DETAIL

[MUT] MANUFACTURER Krohne
MODEL IFC 100W
SERIAL NUMBER C12501983
FUSE Wall switch to right of unit

PLANT ID Southampton WWTP
METER ID Return Activated Sludge #2 (East Side)
FIT ID N/A
CLIENT TAG N/A
OTHER ORG #5613
GPS COORDINATES N44 30.103 W081 21.236

VERIFICATION DATE May 16, 2023
CAL. FREQUENCY Annual
CAL. DUE DATE May, 2024

PROGRAMMING PARAMETERS

DIAMETER (DN)	mm	150
F.S. FLOW - MAG	LPS	165.9
F.S. RANGE - O/P	LPS	63.09
CAL. K-FACTOR	GKL	6.1613

FORWARD TOTALIZER INFORMATION

AS FOUND	5676944.25	M3
AS LEFT	5676950.56	M3
DIFFERENCE	6.31	M3

TEST CRITERIA

AS FOUND CERTIFICATION TEST	Yes
FORWARD FLOW DIRECTION	Yes
ALLOWABLE [%] ERROR	5

COMPONENTS TESTED

CONVERTER DISPLAY	yes
mA OUTPUT	yes
TOTALIZER	Yes
ACCURACY BASED ON [% o.r.]	yes
ERROR DOCUMENTED IN THIS REPORT; BASED ON % o.r.	

Zero Offset Flow LPS 0.0000

FLOW TUBE SIMULATION

		0.0	0.5	1.0	2.0	m/s
		0.0	5.0	10.0	20.0	% F.S. Flow
		0.0	13.2	26.3	52.6	% F.S. Range
REF. FLOW RATE		0.0		8.3	16.6	33.2
MUT [Reading]		0.0		8.3	16.6	33.2
MUT [Difference]		0.0		0.0	0.0	0.0
MUT [% Error]		n/a		0.04	0.04	0.04
mA OUTPUT		4.000		6.104	8.208	12.416
MUT [Reading]	min.	4.000 mA		4.000	6.114	12.425
MUT [Difference]	max.	20.000 mA		0.000	0.010	0.009
MUT [% Error]				0.00	0.16	0.07
TOTALIZER - REF. FLOW RATE					33.186	LPS
TOTALIZER [MUT]					2	M3
TEST TIME					59.77	SECONDS
CALC. TOTALIZER					1.984	M3
ERROR					0.82	%

COMMENTS

QUALITY MANAGEMENT STANDARDS INFO.		
[QMS] INFORMATION	IDENT.	ID #
[REFERENCE] FTS	KRO	1
PROCESS METER	PM	20
ANALOG METER	AM	N/A
STOP WATCH	SW	yes

RESULTS

TEST	AVG % o.r.	PASS FAIL
DISPLAY	0.04	PASS
mA OUTPUT	0.10	PASS
TOTALIZER	0.82	PASS

This report reflects the test results of the overall accuracy for the above flow converter using the specified manufacturers flow tube simulator to within the specified tolerance as identified within this report.



AS FOUND CERTIFICATION

PASS

CLIENT DETAIL

CUSTOMER OCWA - Georgian Highlands - Bruce Hub
CONTACT Dan MacLeod
Senior Operations Manager
18 Caroline Street West
Southampton, ON N0H 2L0
Ph: 519-379-0431
E: danmacleod@ocwa.com

VER. BY - FM Paris Machuk / Mike White

Quality Management Standards Information -
Reference equipment and instrumentation used to
conduct this verification test is found in our AC-
QMS document at the time this test was

EQUIPMENT DETAIL
[MUT] MANUFACTURER Greyline
MODEL OCM (SLT-32)
CONVERTER SERIAL NUMBER 38872-R

PLANT ID Southampton WWTP
METER ID Final Effluent
FIT ID LIT-1
CLIENT TAG OCWA# 74302
OTHER ORG# 5613
GPS COORDINATES N44 30.103 W081 21.236

VERIFICATION DATE May 16, 2023
CAL. FREQUENCY Annual
CAL. DUE DATE May, 2024

PROGRAMMING PARAMETERS

NOTCH ANGLE (φ)	inches	90
EMPTY DISTANCE, TX to notch	m	0.755
TRANSDUCER (TX), to sump flc	m	1.112
SUMP LEVEL, zero flow	m	0.357
MAX. HEAD	m	0.325
BLANKING DISTANCE	m	0.305
DEAD ZONE	m	0.125
MAX. FLOW	M3/D	7179.6
F.S. RANGE - O/P	M3/D	7179.6

TOTALIZER
AS FOUND 9704550 M3
AS LEFT 9704601 M3
DIFFERENCE 51 M3

TEST CRITERIA
AS FOUND CERTIFICATION TEST Yes
ALLOWABLE [%] ERROR 15

COMPONENTS TESTED
CONVERTER DISPLAY yes
mA OUTPUT yes
TOTALIZER yes
ACCURACY BASED ON [% o.r.] No

Ultrasonic sensor installed to ensure full scale flow condition

ERROR DOCUMENTED IN THIS REPORT; BASED ON % F.S.

AS FOUND TEST RESULTS

		42.1	57.2	68.9	81.9	96.2	% F.S. Range
		0.230	0.260	0.280	0.300	0.320	m
REF. FLOW RATE		3024.9	4109.9	4946.4	5877.5	6906.7	M3/D
MUT [Reading]		3198.0	4286.0	5219.0	6136.0	7181.0	M3/D
MUT [Difference]		173.1	176.1	272.6	258.5	274.3	M3/D
MUT [% Error]		2.4	2.5	3.8	3.6	3.8	%
mA OUTPUT		10.741	13.159	15.023	17.098	19.392	mA
MUT [Reading]	min.	4.000 mA	11.136	13.524	15.629	17.665	mA
MUT [Difference]	max.	20.000 mA	0.395	0.365	0.606	0.567	mA
MUT [% Error]			1.97	1.83	3.03	2.83	%
TOTALIZER - REF. FLOW RATE						6906.655	M3/D
TOTALIZER [MUT]						5	M3
TEST TIME						57.43	SECONDS
CALC. TOTALIZER						4.591	M3
ERROR						8.18	%

COMMENTS

QUALITY MANAGEMENT STANDARDS INFO.

[QMS] INFORMATION	IDENT.	ID #
[REFERENCE] LEVEL	Sim. BOARD	Yes
PROCESS METER	PM	20
STOP WATCH	SW	Yes

RESULTS

TEST	AVG %FS	PASS FAIL
DISPLAY	3.42	PASS
mA OUTPUT	2.53	PASS
TOTALIZER	8.18	PASS

This report reflects the test results of the overall accuracy for the above flow converter using the specified manufacturers flow tube simulator to within the specified tolerance as identified within this report.

Proportional Weir



Customer OCWA - Southampton Area
 Contact Dan MacLeod
 Cluster Manager
 519-370-0431
 Test Performed By: Paris Machuk / Mike White
 Field Representative

Plant ID	Southampton WWTP	Date of Verification	16-May-23
Meter ID	Influent - South Channel	Calibration Frequency	Annual
FIT ID	n/a	Date of Next Verification	May-24
Client Tag	OCWA# 74303		
GPS Coordinates	N44 30.103 & W081 21.236		

Converter Details

Manufacturer	Greyline	As Found	10891172 m3
Model	SLT32-A	As Left	10891196 m3
Converter S/N:	38873-R	Difference	24 m3
Fuse	Panel		

Programming Parameters

Weir Type	Proportional	Steel Ruler/Simulation Board	Yes
Weir Length	m	Digital Multimeter (DMM)	3
Max. Head	0.326	Stop Watch	1/100 th second
Max. Flow	5888.65		
Max Range	0.726	Display Accuracy Verified	Yes
		mA Output Accuracy Verified	Yes
		Totalizer Accuracy Verified	Yes

Note: off set from zero to bottom of South channel = 133mm

Note: off set from zero to bottom of North channel = 138mm

AS FOUND	0	31%	61%	92%	98%	% F.S. Flow
FLOW TUBE SIMULATION*	0.00001	0.100	0.200	0.300	0.320	m
Display	0.000	1806.335	3612.669	5419.004	5780.271	m3/d
MUT (As Found)	0.00	1673.00	3525.00	5355.00	5687.00	m3/d
MUT (Error)**	n/a	-2.26%	-1.49%	-1.09%	-1.58%	%
mA Output	4.000	8.908	13.816	18.724	19.706	mA
MUT (As Found)	4.004	8.535	13.579	18.550	19.460	mA
MUT (Error)**	0.10	-4.19	-1.72	-0.93	-1.25	%
Totalizer					5780.271	m3/d
Test Volume					5	m3
Time					77.40	Seconds
Calc. Flowrate					5581.40	m3/d
% Error					-3.44	%

* All values are for "As Found" values. If the values are not within acceptable limits an "As Left" certificate will be issued unless otherwise noted.

Comments

Error represented as % of full scale
 Grey Line K&n factor for Q calc is k=458.809 and n = 1 for Greyline OCF calibration
 k=2.25038 n=1
 Checked Weir Zero and found to be good.

Note: checked South Side @ head 0.0m unit reading: HEAD=0.0m
 @ head 0.32m unit reading: HEAD=0.315m

Results

	Avg. % Error	PASS/FAIL
Display	-0.02	PASS
mA Output	-2.02	PASS
Totalizer	-3.44	PASS

This record only validates the operational integrity and accuracy verification results of the Secondary flow converter ONLY!!! This is not a complete calibration of the entire flow meter whereby, this verification does not validate the integrity of the primary measurement device using a comparative technique or traceable standard.



AS FOUND CERTIFICATION
FORWARD FLOW DIRECTION
PASS

CLIENT DETAIL

CUSTOMER OCWA - Georgian Highlands - Bruce Hub
CONTACT Dan MacLeod
Senior Operations Manager
18 Caroline Street West
Southampton, ON N0H 2L0
Ph: 519-379-0431
E: danmacleod@ocwa.com

VER. BY - FM Paris Machuk / Mike White

Quality Management Standards Information -
Reference equipment and instrumentation used to
conduct this verification test is found in our AC-
QMS document at the time this test was

EQUIPMENT DETAIL

[MUT] MANUFACTURER Krohne
MODEL IFC100W
SERIAL NUMBER C10 1442
FUSE in Panel ULF4

PLANT ID Southampton PS#4
METER ID Station Flow
FIT ID FIT-01
CLIENT TAG OCWA #??
OTHER n/a
GPS COORDINATES N44 30.969 W081 21.481

VERIFICATION DATE May 15, 2023
CAL. FREQUENCY Annual
CAL. DUE DATE May, 2024

PROGRAMMING PARAMETERS

DIAMETER (DN)	mm	150
F.S. FLOW - MAG	LPS	163.0
F.S. RANGE - O/P	LPS	100.0
CAL. K-FACTOR	GKL	6.05280

FORWARD TOTALIZER INFORMATION

AS FOUND	319468.45	M3
AS LEFT	319484.38	M3
DIFFERENCE	15.93	M3

TEST CRITERIA

AS FOUND CERTIFICATION TEST	Yes
FORWARD FLOW DIRECTION	Yes
ALLOWABLE [%] ERROR	5

COMPONENTS TESTED

CONVERTER DISPLAY	Yes
mA OUTPUT	Yes
TOTALIZER	Yes
ACCURACY BASED ON [% o.r.]	Yes

Zero Offset Flow LPS 0 ERROR DOCUMENTED IN THIS REPORT; BASED ON % o.r.

FLOW TUBE SIMULATION

		0.0	0.5	1.0	2.0	5.0	m/s
		0.0	5.0	10.0	20.0	50.0	% F.S. Flow
		0.0	8.2	16.3	32.6	81.5	% F.S. Range
REF. FLOW RATE		0.0	8.2	16.3	32.6	81.5	LPS
MUT [Reading]		0.0	8.1	16.2	32.5	81.4	LPS
MUT [Difference]		0.0	-0.1	-0.1	-0.1	-0.1	LPS
MUT [% Error]		n/a	-0.62	-0.62	-0.31	-0.13	%
mA OUTPUT		4.000	5.304	6.608	9.216	17.041	mA
MUT [Reading]	min.	4.000	3.998	5.288	6.594	9.202	mA
MUT [Difference]	max.	20.000	-0.002	-0.016	-0.014	-0.009	mA
MUT [% Error]			-0.05	-0.30	-0.21	-0.16	%
TOTALIZER - REF. FLOW RATE						81.505	LPS
TOTALIZER [MUT]						9	M3
TEST TIME						110.40	SECONDS
CALC. TOTALIZER						8.998	M3
ERROR						0.02	%

COMMENTS

QUALITY MANAGEMENT STANDARDS INFO.		
[QMS] INFORMATION	IDENT.	ID #
[REFERENCE] FTS	KRO	1
PROCESS METER	DMM	1
ANALOG METER	AM	N/A
STOP WATCH	SW	YES

RESULTS		
TEST	AVG % o.r.	PASS FAIL
DISPLAY	-0.42	PASS
mA OUTPUT	-0.15	PASS
TOTALIZER	0.02	PASS

This report reflects the test results of the overall accuracy for the above flow converter using the specified manufacturers flow tube simulator to within the specified tolerance as identified within this report.



AS FOUND CERTIFICATION
FORWARD FLOW DIRECTION
PASS

CLIENT DETAIL

CUSTOMER OCWA - Georgian Highlands - Bruce Hub
CONTACT Dan MacLeod
Senior Operations Manager
18 Caroline Street West
Southampton, ON N0H 2L0
Ph: 519-379-0431
E: danmacleod@ocwa.com

VER. BY - FM Paris Machuk / Mike White

Quality Management Standards Information -
Reference equipment and instrumentation used to
conduct this verification test is found in our AC-
QMS document at the time this test was

EQUIPMENT DETAIL

[MUT] MANUFACTURER Krohne
MODEL IFC100W
SERIAL NUMBER C185000439
FUSE in Panel ULF4

PLANT ID Southampton PS#5
METER ID Station Flow
FIT ID FIT-02
CLIENT TAG OCWA #??
OTHER n/a
GPS COORDINATES N44 30.347 W081 22.196

VERIFICATION DATE May 15, 2023
CAL. FREQUENCY Annual
CAL. DUE DATE May, 2024

PROGRAMMING PARAMETERS

DIAMETER (DN)	mm	200
F.S. FLOW - MAG	LPS	406.9
F.S. RANGE - O/P	LPS	120.0
CAL. K-FACTOR	GKL	8.4993

FORWARD TOTALIZER INFORMATION

AS FOUND	1770571.81	M3
AS LEFT	1770587.52	M3
DIFFERENCE	15.71	M3

TEST CRITERIA

AS FOUND CERTIFICATION TEST	Yes
FORWARD FLOW DIRECTION	Yes
ALLOWABLE [%] ERROR	5

COMPONENTS TESTED

CONVERTER DISPLAY	Yes
mA OUTPUT	Yes
TOTALIZER	yes
ACCURACY BASED ON [% o.r.]	Yes
ERROR DOCUMENTED IN THIS REPORT; BASED ON % o.r.	

Zero Offset Flow LPS 0

FLOW TUBE SIMULATION

		0.0	0.5	1.0	2.0	m/s
		0.0	5.0	10.0	20.0	% F.S. Flow
		0.0	17.0	33.9	67.8	% F.S. Range
REF. FLOW RATE		0.0		20.3	40.7	81.4
MUT [Reading]		0.0		20.3	40.6	81.3
MUT [Difference]		0.0		0.0	-0.1	-0.1
MUT [% Error]		n/a		-0.23	-0.23	-0.11
mA OUTPUT		4.000		6.713	9.426	14.851
MUT [Reading]	min.	4.000 mA	3.999	6.701	9.416	14.848
MUT [Difference]	max.	20.000 mA	-0.001	-0.012	-0.010	-0.003
MUT [% Error]			-0.02	-0.18	-0.10	-0.02
TOTALIZER - REF. FLOW RATE					81.386	LPS
TOTALIZER [MUT]					9.00	M3
TEST TIME					110.87	SECONDS
CALC. TOTALIZER					9.023	M3
ERROR					-0.26	%

COMMENTS

QUALITY MANAGEMENT STANDARDS INFO.		
[QMS] INFORMATION	IDENT.	ID #
[REFERENCE] FTS	KRO	1
PROCESS METER	DMM	20
ANALOG METER	AM	N/A
STOP WATCH	SW	YES

RESULTS

TEST	AVG % o.r.	PASS FAIL
DISPLAY	-0.19	PASS
mA OUTPUT	-0.08	PASS
TOTALIZER	-0.26	PASS

This report reflects the test results of the overall accuracy for the above flow converter using the specified manufacturers flow tube simulator to within the specified tolerance as identified within this report.



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southhampton						
Plant Name and address:	86 Saugeen St ON						
Service Date:	17-Oct-23	Instrument Type:	AIT	W.O. Number:	230882-0001	Asset#:	NA
Due Date:	17-Apr-24	Manufacturer:	MSA				
Follow-Up Required:	No	Model:	ULTIMA - X 5000				
As Left Status:	Initial Condt	Serial #:	000100200115001C				
Instrument Visual Inspection:		Range:	0-25 O2%, 0- 50 PPM H2S	Output:	4-20 mA		
Mechanical Inspection:	OK	Tag Infomration:	NA				
Electrical Inspection:	OK	Description:	Monitoring Oxygen Gas & H2S Gas				
As found Display information:	OK	Process/Location Description:	Saugeen St pumping station				

Instrument Information:								
Sensor No.:	Sensor Type	Unit	Zero Gas Value	Span Gas Value	Range Gas Value	Caution Setpoint	Warning Setpoint	Alarm Setpoint
1	O2	%	0	20.80	0-25	NA	19.50	18.00
2	H2S	PPM	0	40	0-50	NA	5.00	15.00

Sensor No.:	Gas	Gas Value	As Found	Deviation	As Left	Deviation
Sensor 1	Zero	0	0	0.00%	0	0.00%
	Span	20.8	20.80	0.00%	20.80	0.00%
Sensor 2	Zero	0	0	0.00%	0	0.00%
	Span	40	38.40	4.00%	40	0.00%

Comments			Test Equipment Used		
			Name / Type	Serial and Due Date	
Calibrated successfully			CalGas Oxygen 20.8% Vol	304-402190658-1, Aug-2025	
			CalGas H2S 40 PPM	304-402184551-1, Aug-2024	
Other Outputs Tested:		Not tested	Technician Name		Witness Name
Loop Check Performed:		Not Tested	Vaibhav Patel		Jusin Porter
Within Specification:		Yes	Date:	17-Oct-23	Date: 17-Oct-23



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southampton										
Plant Name and address:	86 Saugeen St ON										
Service Date:	17-Oct-23	Instrument Type:	AIT	W.O. Number:	230882-0001	Asset#:	NA				
Due Date:	17-Apr-24	Manufacturer:	MSA								
Follow-Up Required:	No	Model:	ULTIMA - X 5000								
As Left Status:	Initial Condt	Serial #:	000100200117001B								
Instrument Visual Inspection:		Range:	0-100% LEL	Output:	4-20 mA						
Mechanical Inspection:	OK	Tag Infomration:	NA								
Electrical Inspection:	OK	Description:	Monitoring Methane Gas								
As found Display information:	OK	Process/Location Description:	Saugeen St pumping station								

Instrument Information:	
Sensor Type and unit:	LEL, %
Zero Gas Value:	0
Span Gas Value:	50
Gas Range Value:	0-100
Caution Level:	NA
Warning Level:	10
Alarm Level:	20

Gas	Gas Value	As Found	Deviation	As Left	Deviation
Zero	0	0	0.00%	0	0.00%
Span	50	52	4.00%	50	0.00%

Comments		Test Equipment Used			
		Name / Type		Serial and Due Date	
Calibrated successfully		CalGas Methane 2.5% Vol (50%)		304-402205618-1, Aug-2025	
		CalGas Oxygen 20.8% Vol		304-402190658-1, Aug-2025	
Other Outputs Tested:	Not tested	Technician Name		Witness Name	
Loop Check Performed:	Not Tested	Vaibhav Patel		Jusin Porter	
Within Specification:	Yes	Date:	17-Oct-23	Date:	17-Oct-23



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southampton						
Plant Name and address:	18 Caroline st, Southampton						
Service Date:	17-Oct-23	Instrument Type:	AIT	W.O. Number:	230882-0001	Asset#:	NA
Due Date:	17-Apr-24	Manufacturer:	MSA				
Follow-Up Required:	No	Model:	ALTAIR 4X				
As Left Status:	Initial Condt	Serial #:	00356341				
Instrument Visual Inspection:		Range:	0-100%,0-100PPM,0-50PPM,0-25%	Output:	NA		
Mechanical Inspection:	OK	Tag Infomration:	NA				
Electrical Inspection:	OK	Description:	MSA ALTAIR 4X Handheld gas				
As found Display information:	OK	Process/Location Description:	Operator room				

Instrument Information:								
Sensor No.:	Sensor Type	Unit	Zero Gas Value	Span Gas Value	Range Gas Value	Caution Setpoint	Warning Setpoint	Alarm Setpoint
1	LEL	%	0	50	100	NA	10.00	10.00
2	CO	PPM	0	100	100	NA	10.00	20.00
3	H2S	PPM	0	25	50	NA	5.00	15.00
4	O2	%	0	18.0	25	NA	19.50	18.00

Sensor No.:	Gas	Gas Value	As Found	Deviation	As Left	Deviation
Sensor 1	Zero	0	0	0.00%	0	0.00%
	Span	50	45	-10.00%	58	50.00%
Sensor 2	Zero	0	0	0.00%	0	0.00%
	Span	100	97	-3.00%	60	100.00%
Sensor 3	Zero	0	0	0.00%	0	0.00%
	Span	25	25	0.00%	20	25.00%
Sensor 4	Zero	0	0	0.00%	0	0.00%
	Span	18.0	18	0.00%	18	18.00%

Comments			Test Equipment Used		
			Name / Type	Serial and Due Date	
Calibrated Successfully			MSA Quadgas	304-402541925-1 ; Sept-2026	
			(100 PPM CO, 25 PPM H2S, 50 %LEL, 18% O2)		
Other Outputs Tested:		Not tested	Technician Name	Witness Name	
Loop Check Performed:		Not tested	Vaibhav Patel	Justin Porter	
Within Specification:		Yes	Date: 17-Oct-23	Date: 17-Oct-23	



CALIBRATION / VERIFICATION

3230B American Dr, Mississauga,
Ontario L4V 1B3. Tel: (905) 678-2882
Email: service@spdsales.com
Web Site: www.spdsales.com

Customer Name:	OCWA - Southampton						
Plant Name and address:	18 Caroline st, Southampton						
Service Date:	17-Oct-23	Instrument Type:	AIT	W.O. Number:	230882-0001	Asset#:	NA
Due Date:	17-Apr-24	Manufacturer:	MSA				
Follow-Up Required:	No	Model:	ALTAIR 4X				
As Left Status:	Initial Condt	Serial #:	199193				
Instrument Visual Inspection:		Range:	0-100%,0-100PPM,0-50PPM,0-25%	Output:	NA		
Mechanical Inspection:	OK	Tag Infomration:	NA				
Electrical Inspection:	OK	Description:	MSA ALTAIR 4X Handheld gas				
As found Display information:	OK	Process/Location Description:	Operator room				

Instrument Information:								
Sensor No.:	Sensor Type	Unit	Zero Gas Value	Span Gas Value	Range Gas Value	Caution Setpoint	Warning Setpoint	Alarm Setpoint
1	LEL	%	0	50	100	10.00	10.00	
2	CO	PPM	0	100	100	10.00	20.00	
3	H2S	PPM	0	25	50	5.00	15.00	
4	O2	%	0	18.0	25	19.50	18.00	

Sensor No.:	Gas	Gas Value	As Found	Deviation	As Left	Deviation
Sensor 1	Zero	0	0	0.00%	0	0.00%
	Span	50	50	0.00%	50	0.00%
Sensor 2	Zero	0	0	0.00%	0	0.00%
	Span	100	104	4.00%	100	0.00%
Sensor 3	Zero	0	0	0.00%	0	0.00%
	Span	25	25	0.00%	25	0.00%
Sensor 4	Zero	0	0	0.00%	0	0.00%
	Span	18.0	18.6	3.33%	18	0.00%

Comments			Test Equipment Used		
			Name / Type	Serial and Due Date	
Calibrated Successfully			MSA Quadgas	304-402541925-1 ; Sept-2026	
			(100 PPM CO, 25 PPM H2S, 50 %LEL, 18% O2)		
Other Outputs Tested:		Not tested	Technician Name	Witness Name	
Loop Check Performed:		Not tested	Vaibhav Patel	Justin Porter	
Within Specification:		Yes	Date: 17-Oct-23	Date: 17-Oct-23	



Appendix E

Community Complaints

SOUTHAMPTON WWTF Logbook

Entry Time	Label	Entry Text	Operator	Created Time
2023-01-04 00:00:00		00:00-23:59 ORO: Justin Porter (jporter) 07:00-15:30 Duty OIC: Justyn Becker (jbecker) 07:00-15:30 OIC: Justin Porter (jporter)	Justin Porter	2023-01-04 13:05:06
2023-01-04 08:07:00		Completed rounds at pump stations, checks good.	Justyn Becker	2023-01-04 08:07:38
2023-01-04 13:05:00	Community Complaint, Facility Checks, Maintenance, Southampton WWTP	<p>Completed morning rounds at wpcp. Checks good - refer to check sheets.</p> <p>Shut off air and took decant off of primary digester.</p> <p>Replaced pH probe on handheld meter. The probe bulb was cracked.</p> <p>Ditch 2 online DO readings not matching hand held readings. Pulled up both ditch 1 and ditch 2 probes to clean and inspect caps. Caps in good conditions. Cleaned probes and returned to service - readings now more consistent with hand held.</p> <p>Drive belt cage on ditch 2 was open during checks. Don't know why it was open. Secured cage shut.</p> <p>Investigated odour complaints with Justyn Becker and SOM Dan MacLeod along Blanchfield and conjoining neighbours. Unable to identify the odours mentioned by residents in complaints submitted to SOM and ToSS.</p> <p>Shovelled grit out of south grit channel and put south channel into service. Removed north channel from service .</p>	Justin Porter	2023-01-04 13:13:02

SOUTHAMPTON WWTF Logbook

Entry Time	Label	Entry Text	Operator	Created Time
2023-01-04 15:00:00		<p>Decanted secondary digester. Transferred ~ 40 cubic meters of sludge secondary to ht4. Finished in house lab from yesterday.</p> <p>Investigated odour complaints coming from north side of Saugeen river with Justin Porter and SOM. Checked manholes in the area and pump stations 4 & 5. Nothing noticed to note.</p> <p>Removed rain catchers for winter season from manholes at Blanchfield and oak and also at Blanchfield and Turner st where ps4 force main goes to gravity.</p>	Justyn Becker	2023-01-04 15:02:55

SOUTHAMPTON WWTF Logbook

Entry Time	Label	Entry Text	Operator	Created Time
2023-01-13 00:00:00		00:00-23:59 ORO: Justin Porter (jporter) 07:00-15:30 Duty OIC: Justin Porter (jporter)	Justin Porter	2023-01-13 15:09:40
2023-01-13 15:09:00	Community Complaint, Facility Checks, Southampton WWTP	<p>Completed am and pm rounds at pump stations and wpcp. Checks good - refer to check sheets for details.</p> <p>Investigated odour complaint at 282 Tyendinaga. Spoke with the resident who mentioned the odour is consistent and most noticeable at the corner of Tyendinaga and Mississauga street. I did not notice any odour in or around the neighborhood, but there was some debris in the manhole at that intersection. Sent findings to SOM.</p> <p>Took garbage to dump. Swept and mopped the floors. Cleaned lab dishes.</p> <p>Took decant off of primary digester.</p> <p>Connected clarifier hose to a functioning hose bib, but the exposed hose going to the clarifier building had froze.</p>	Justin Porter	2023-01-13 15:13:52

SOUTHAMPTON WWTF Logbook

Entry Time	Label	Entry Text	Operator	Created Time
2023-01-19 00:00:00		00:00-23:59 ORO: Justin Porter (jporter) 07:00-15:30 Duty OIC: Justyn Becker (jbecker) 07:00-15:30 OIC: Justin Porter (jporter)	Justin Porter	2023-01-19 15:11:02
2023-01-19 09:49:00	Facility Checks	PanelView plus 1000 displaying "Application MERuntime.exe encountered a serious error and must be shut down", during morning checks. Reset power to screen and acknowledged/cleared alarm queue, no issues after reset. Skimmed clarifiers and pulled rags off bar screens. Measured Alum flow to be 56 mL/min at west pit and 58 mL/min at east pit since balancing yesterday.	Justyn Becker	2023-01-19 09:50:28
2023-01-19 15:16:00	Facility Checks, Maintenance, PS5	Completed am rounds at pump stations. Attended ops meeting at wpcp. Checked check valves at pump station 5. No negative flow seen on the flow meter after a pump run. Peak flow rate on pump 3 was about 10 lps lower then pump 4. Recommend lifting and inspecting pumps. Checking well for obstructions. Picked up new battery for y2k genset	Justin Porter	2023-01-19 15:29:38
2023-01-19 16:00:00		Attended monthly OPS meeting. Wasted sludge to primary digester and ht1. Replaced 5 burnt out 4 ft fluorescent ceiling light bulbs in mens bathroom and lab with new LED bulbs provided by ToSS electrician. Investigated bad smell complaint from area around ps5 with SOM. Only noticed a slight smell on pedestrian walking path approximately one meter from wet well. Completed Thursday in house lab. Completed pm rounds at WWTP. Shut off air to ht1 to decant tomorrow.	Justyn Becker	2023-01-20 15:01:07

SOUTHAMPTON WWTF Logbook

Entry Time	Label	Entry Text	Operator	Created Time
2023-07-06 00:00:00		00:00-23:59 ORO: Justin Porter (jporter) 07:00-15:30 Duty OIC: Justyn Becker (jbecker) 07:00-15:30 OIC: Justin Porter (jporter)	Justin Porter	2023-07-06 15:57:20
2023-07-06 15:15:00		Assisted with morning checks at WWTP. Decanted primary digester. Transferred sludge from primary to secondary and ht4 after decant. Tradesafe on site doing annual inspection of lifting equipment.	Justyn Becker	2023-07-06 15:17:05
2023-07-06 15:57:00	Community Complaint, Facility Checks, PS5, Southampton WWTP	Completed am and pm checks at pump stations and wpcp with the assistance of JB. Wasted to holding tank 1. Worked with Dan MacLeod investigating odour complaints along shore road. Reference Maximo work order 3480013 log for details. Entered June rounds data into Wiski7	Justin Porter	2023-07-06 15:59:32

Dan MacLeod and I went to investigate the continuing odour complaints along Shore Road.

These complaints described the odour along Shore Road and Deer Run Ct, just north of pump station 5.

We were able to smell faint odour at the intersection of Shore and Deer Run. We removed a rain catcher at the dead end of Deer Run, and put it at the intersection. Ordered an additional rain catcher for the man hole immediately after the intersection towards the beach.

Deodourizer was poured down each manhole inspected. Dan suggested we incorporate deodourizing the dead end at Deer Run into weekly checks, hoping the low flow and ample benching would provide space for the deodourizer to sit, and flow down towards the other man holes when flow goes through.

SOUTHAMPTON WWTF Logbook

Entry Time	Label	Entry Text	Operator	Created Time
2023-06-22 00:00:00		00:00-23:59 ORO: Joshua Marx (jmarx) 07:00-15:30 Duty OIC: Justin Porter (jporter)	Justin Porter	2023-06-22 15:11:07
2023-06-22 15:11:00	Community Complaint, Facility Checks, Health & Safety, Maintenance, PS1, PS5, Southampton WWTP	<p>Completed am and pm rounds at pump stations and wpcp. Noticed wet well ventilation fan off at pump station 1, and LEL elevated on gas monitoring (still working safe limits). Turned fan on to bring fresh air down to well. De ragged RAS pump 2. All other checks good.</p> <p>Measured alum flow at 120 ml/min.</p> <p>Installed new belt on blower 4. Cleaned and aligned pulleys.</p> <p>Installed new emergency exit sign above the door leading to the stair way from the map/server room after noticing old sign flickering.</p> <p>Cleaned north grit channel after switching to south grit channel.</p> <p>Investigated odour complaint by pump station 5. No odour noticed. Poured deodorizer down wet well, flow meter pit, adjacent catch basins, and the near by gravity sewer entering wet well 5. Turned well ventilation fan back on after it had been off for weeks.</p>	Justin Porter	2023-06-22 15:20:07

SOUTHAMPTON WWTF Logbook

Entry Time	Label	Entry Text	Operator	Created Time
2023-10-19 11:30:00		06:30-17:00 OIC: Justyn Becker (jbecker) 00:00-23:59 ORO: Joshua Marx (jmarx) 07:00-15:30 Duty OIC: Nicole Moore (nmoore)	Justyn Becker	2023-10-19 18:01:05
2023-10-19 11:31:00		Changed chart at wpcp all checks good, took set test and took DO and temp and pH.	Nicole Moore	2023-10-19 11:32:14
2023-10-19 11:34:00		Received rebuild blow motor from trucking company, dropped off in shop.	Nicole Moore	2023-10-19 11:35:01
2023-10-19 13:31:00		Investigated possible sewage smell in area around 281 Edward st with SOM. Opened closest manhole to address. Nothing out of ordinary to note.	Justyn Becker	2023-10-20 07:40:38
2023-10-19 17:02:00	Facility Checks	On site early starting rounds at pump stations. Completed morning checks at WWTP. Skimmed clarifiers and pulled rags off bar screens. Wasted sludge to primary digester. Completed afternoon rounds at WWTP.	Justyn Becker	2023-10-19 18:09:11